


QUOTATION

Name of work :- Provide the connection point for connecting UPS at ground floor of Prefabricated block-A near Media Lab.

S.No	Description	Qty	Unit	Rate	Amount
(In Words & Figures)					
1	Supplying & drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface / recessed steel / PVC conduit as reqd.				
1.1	3 x 6 Sq.mm..	70.00	Mtr.		
2	Supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 volts, on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator)				
2.1	8-way , Double door	1.00	Nos.		
3	Supplying and fixing 5 amps to 32 amps rating, 240 volts, 'C' series, MCB suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as reqd.				
3.1	Single Pole	8.00	Nos.		
3.2	Triple Pole	1.00	Nos.		
4	Supplying & drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface / recessed steel / PVC conduit as reqd.				
4.1	3 x 16 Sq.mm..	34.00	Mtr.		
5	Supplying and fixing 40 amp to 63 amp rating 240 volts 'C' curve 10 kA MCB of following pole in the existing MCB DB complete with connection, testing & commissioning etc as reqd.				
5.1	Four Pole	1.00	Nos		

S.No	Description	Qty	Unit	Rate (In Words & Figures)	Amount
6	Supplying and fixing Al tube / reducer terminals suitable for following size of conductor.				
6.1	6 /10/16 Sq.mm.	70.00	Nos.		
7	Providing and fixing DLP plastic trunking of size 105 mm x 50 mm without cover on surface as reqd.	20.00	Mtr.		
8	Providing and fixing DLP plastic trunking of size 105 mm x 50 mm accessories on surface as reqd.				
8.1	PVC trunking full cover of size 85 mm size	20.00	Mtr.		
8.2	End cap	3.00	Nos.		
8.3	Internal angle.	3.00	Nos.		
8.4	External angle	2.00	Nos.		
8.5	flat angle	7.00	Nos.		
8.6	cover joint	3.00	Nos.		
8.7	Base joint	2.00	Nos.		

Total Rs.


 अधिकायी अभियंता (वि०) E.E. (Elect.
 कर्मचारी, मासुडी संस्थान, काठमाडौं
 J.W.D., I.L.T., Kano
