

INDIAN INSTITUTE OF TECHNOLOGY KANPUR
INSTITUTE WORKS DEPARTMENT
ELECTRICAL & AIR-CONDITIONING DIVISION

No. 09/AC/EE/2021/44

Dated 20-05-2021

QUOTATION NOTICE

M/s

Sealed quotations are invited from the Empanelled contractor by the undersigned on behalf of the Director, IIT Kanpur for "Providing and fixing data points in H-11 (mess office), H-8 (Chaupaty) & Power points at H-9 (Mess hand drier) , GH-1st (Sanitary napkin disposal machine), VH (Corridor), GH- Tower block C & D (softening plant)." As per enclosed Bill of Quantity/ overleaf, so as to reach in this office on or before 31-05-2021 upto 3.00 PM and the quotation will be opened on the same day at 3.30PM in the presence of quotationers or their representative who want to be present.

The terms and conditions of the quotation are as under:

1. The quotations should be submitted in a properly sealed envelop, addressed to the undersigned. The enquiry nos. and date should invariably quoted on the top of the envelop.
2. The time allowed for carrying out the above noted work is 28(Twenty Eight) Days.
3. The rates quoted should be exclusive of GST, no other tax is payable except GST. GST shall be applicable as per Govt. norms..
4. Security @ 7.5% shall be deducted from the bills which shall be released on successful completion of defect liability period of six months.
5. The estimated cost of quotation is **Rs.109812/-**. The required earnest money of **Rs. 2196/-** is to be submitted in the form of FDR pledged in favour of the Director, IIT Kanpur alongwith the quotation. The earnest money of the unsuccessful quotationers will be returned within one month's time.
6. The quotations shall remain valid for 90 days from the date of opening.
7. Income tax will be recovered as per notification of Government from the bill and the amount so recovered will be deposited in the State Bank of India at the credit of the firm.
8. The earnest money/Security deposit will be regulated as per the norms of C.P.W.D.
9. The Institute reserves the right of accepting or rejecting any quotations without assigning any reason thereof.
10. The material should be used as per approved list of make.

QUOTATION

Sub: Providing and fixing data points in H-11 (mess office), H-8 (Chaupaty) & Power points at H-9 (Mess hand drier) , GH-1st (Sanitary napkin disposal machine), VH (Corridor), GH- Tower block C & D (softening plant).

S.N.	Description	Qty.	Unit	Rate (Rs.) Words & Fig.	Amount
1	Supplying & drawing following sizes of FRLS PVC insulated copper conductor single core cable in / on the existing surface / recessed, PVC / steel conduit as reqd.				
a)	3 x 4 Sq.mm..	150.00	Mtr.		
2	S & F of following size of steel conduit along with the accessories in surface/recess l/c painting in case of surface conduit or cutting the wall and making good the same in case of recessed conduit as reqd.				
a)	25 mm 16 SWG	10.00	Mtr.		
3	S & F metal box of following sizes (nominal size) on surface or recess with suitable size of 3 mm phenolic laminated sheet cover in the front l/c painting etc as reqd.				
a)	100 mm x 100 mm x 60 mm deep	2.00	Nos.		
b)	180 mm x 100 mm x 60 mm deep	2.00	Nos.		
4	S& F following size/module, GI box along with modular base and cover plate for modular switches in recess as required.				
a)	3 module	2.00	Nos.		
b)	6 module	25.00	Nos.		

S.N.	Description	Qty.	Unit	Rate (Rs.) Words & Fig.	Amount
c)	12 module	1.00	No.		
5	Supply and fixing following modular switch/ socket on the existing modular plates & switch box including connection but excluding modular plate etc. as reqd.				
a)	5/6 Amp one way switch	25.00	Nos.		
b)	3 Pin 5/6 Amp. socket outlet	25.00	Nos.		
c)	15/16 Amp. one way switch	25.00	Nos.		
d)	6 Pin 15/16 Amp. socket outlet.	25.00	Nos.		
e)	Modular type blanking plate.	5.00	Nos.		
6	Supplying and fixing 20 amps 415 volts, TPN industrial type, socket outlet with 4 pole earthing metal enclosure, metal plug top, along with 20 amps, 10 KA, TP MCB on surface or in recess with chained cover for the socket outlet and complete as reqd.	1.00	No.		
7	Supplying and fixing 30 A, 415 V, TPN Industrial type socket outlet, with 4 pole and earth, metal enclosed plug top along with 30 A "C" curve, TPMCB, in sheet steel enclosure, on surface or in recess, with chained metal cover for the socket outlet and complete as reqd.	1.00	No.		
8	S & F MCB of following pole and rating 240/415 volts 'C' series in the existing MCB DB complete with connection, testing & commissioning etc as reqd. (legrand)				
a)	Single Pole 6 amp to 32 amp	5.00	Nos.		

S.N.	Description	Qty.	Unit	Rate (Rs.) Words & Fig.	Amount
b)	Single Pole & Neutral 6 amp to 32 amp	1.00	No.		
c)	Triple Pole 6 amp to 32 amp	1.00	No.		
d)	Triple pole & Neutral 6 amp to 32 amp	1.00	No.		
9	Supplying and fixing following rating, double pole, (single phase and neutral), 240 V, residual current circuit breaker (RCCB), having a sensitivity current 300 mA in the existing MCB DB complete with connections, testing and commissioning etc. as required.				
a)	25-32 amp double pole RCCB	5.00	Nos.		
b)	40 amp double pole RCCB	2.00	Nos.		
10	Supplying and fixing TP sheet steel enclosure on surface/ recess along with 16/25/32 A 415 V "C" curve TP MCB complete with connections, testing and commissioning etc. as required.	1.00	No.		
11	Fixing following size PVC/ MS box on surface/recessed including painting, making good with enamel paint etc. As reqd.				
a)	Up to size 100 mm x 100 mm x 75 mm	5.00	Nos.		
12	Providing & fixing of size 32 mm x 12.5 mm. DLP mini trunking system with independent cover as reqd.	200.00	Mtrs		
13	Providing & fixing accessories for following size of DLP mini trunking system as reqd. (32 mm x 12.5 mm.)				
a)	Flat junction	10.00	Nos.		

S.N.	Description	Qty.	Unit	Rate (Rs.) Words & Fig.	Amount
b)	Changeable flat angle	20.00	Nos.		
c)	Changeable internal /External angle	40.00	Nos.		
d)	End cap left or right	15.00	Nos.		
14	Providing & fixing of size 32 mm x 20 mm. DLP mini trunking system with independent cover as reqd.	55.00	Mtrs		
15	Providing & fixing accessories for following size of DLP mini trunking system as reqd. (32 mm x 20 mm.)				
a)	Flat junction	5.00	Nos.		
b)	Changeable flat angle	10.00	Nos.		
c)	Changeable internal /External angle	10.00	Nos.		
d)	End cap left or right	5.00	Nos.		
16	Supplying and laying of following size DWC HDPE pipe ISI marked along with all accessories like socket, bend, couplers etc.conforming to IS 14930, Part II complete with fitting and cutting, jointing etc. in the existing trench, complete as required				
a)	63 mm dia (OD-63 mm & ID-51 mm nominal)	5.00	Mtr.		

S.N.	Description	Qty.	Unit	Rate (Rs.) Words & Fig.	Amount
17	Supplying and laying of following size DWC HDPE pipe ISI marked along with all accessories like socket, bend, couplers etc. conforming to IS 14930, Part II complete with fitting and cutting, jointing etc.direct in ground (75 cm below ground level) including excavation and refilling the trench but excluding sand cushioning and protective covering etc., complete as required.				
a)	63 mm dia (OD-63 mm & ID-51 mm nominal)	5.00	Mtr.		
18	Drawing of RG-6 cable / network cable/ wiring cable/ telephone cable in existing surface /concealed conduits reqd.	300.00	Mtrs		

Total Rs.



अधिकारी अखिलेश (आर) E.E. (A.C.)
 जलविभागी, महाराष्ट्र सरकार, काठगुड
 T.W.D., I.I.T. Kanpur