

INDIAN INSTITUTE OF TECHNOLOGY RAJASTHAN
MBM Engineering College Campus, Ratanada, Jodhpur – 342011.

Corrigendum
to
TENDER FOR SUPPLY & INSTALLATION OF UPS
Tender Enquiry No. IITJ/2010-11/IT/13 dated 08 October, 2010

Date: 28th October 2010

1. Clause 2: Eligibility Criteria of Bidders:

- **Original content:** Bidder should be financially sound to execute the order. Certificate to this effect should be issued by any Nationalized/Scheduled bank.

Correction: Bidder should be financially sound to execute the order. Certificate to this effect should be issued by any Nationalized/Scheduled bank. *The bidder must attach the balance sheet of the company in this regard.*

3. Warranty: Comprehensive 3 years on-site warranty including Battery replacement.

4. Annexure - II : Technical Specifications

S. No.	Parameters	Specifications	Offered Specs.	Compliance (Yes/No)
3	Capacity	<ol style="list-style-type: none">1. 30 KVA UPS: Modular True Online UPS (expandable to 100 KVA) with 25-30 minutes back-up for the entire UPS.2. 60 KVA Modular True Online UPS [expandable to 100 KVA] with 25-30 minutes back-up with the entire UPS.3. Optional cost for 30 KVA module (1x30 or 3x10) True Online UPS [add on to above] with 25-30 minutes back-up. <ul style="list-style-type: none">• Modules must be rack-mountable, hot swappable. Each module must have a rectifier, a charger and an inverter module built into it.• The minimum capacity of each module should not be less than 10 KVA.		
11	Battery Warranty	3 Years Comprehensive warranty including battery replacement		

13	Manual and static bypass	Built-in		
	Isolation Transformer	Optional 30 KVA rating to be provided at input externally.		
	Average MTTR	4 Hours		
	MTBF	1,50,000 Hours		
19	Battery Make	Global Yuasa/Exide/HBL/Panasonic		
	UPS Make	Quotations are invited from reputed companies like Emerson/ APC/ Numeric/ Eaton/ GE/ Liebert/ Gutor/Chloride/Mitsubishi		