



HVAC - LEGENDS

MARK	DESCRIPTION
	SUPPLY AIR DUCT
	FRESH AIR DUCT
	RETURN AIR DUCT
	SMOKE EXHAUST DUCT
	SIDE THROW GRILLE
	DOWN THROW 2 SLOT DIFFUSER
	FLEXIBLE DUCT
	EXHAUST AIR GRILLE
	TRAP DOOR
	INLINE FAN
	REFRIGERANT PIPE



TENDER DRAWING

<p>GUEST ROOM-21 1# 1.6 TR VRF BASED DUCTABLE UNIT SIZE:-900(W)x750(D)x300(H) FRESH AIR 30 CFM EXHAUST AIR 40 CFM</p>	<p>GUEST ROOM-22 1# 1.3 TR VRF BASED DUCTABLE UNIT SIZE:-900(W)x750(D)x300(H) FRESH AIR 30 CFM EXHAUST AIR 40 CFM</p>	<p>GUEST ROOM-23 1# 1.6 TR VRF BASED DUCTABLE UNIT SIZE:-900(W)x750(D)x300(H) FRESH AIR 30 CFM EXHAUST AIR 40 CFM</p>	<p>GUEST ROOM-24 1# 1.3 TR VRF BASED DUCTABLE UNIT SIZE:-900(W)x750(D)x300(H) FRESH AIR 30 CFM EXHAUST AIR 40 CFM</p>	<p>GUEST ROOM-25 1# 1.6 TR VRF BASED DUCTABLE UNIT SIZE:-900(W)x750(D)x300(H) FRESH AIR 30 CFM EXHAUST AIR 40 CFM</p>	<p>GUEST ROOM-26 1# 1.3 TR VRF BASED DUCTABLE UNIT SIZE:-900(W)x750(D)x300(H) FRESH AIR 30 CFM EXHAUST AIR 40 CFM</p>
<p>GUEST ROOM-27 1# 1.6 TR VRF BASED DUCTABLE UNIT SIZE:-900(W)x750(D)x300(H) FRESH AIR 30 CFM EXHAUST AIR 40 CFM</p>	<p>GUEST ROOM-28 1# 1.3 TR VRF BASED DUCTABLE UNIT SIZE:-900(W)x750(D)x300(H) FRESH AIR 30 CFM EXHAUST AIR 40 CFM</p>	<p>GUEST ROOM-29 1# 1.6 TR VRF BASED DUCTABLE UNIT SIZE:-900(W)x750(D)x300(H) FRESH AIR 30 CFM EXHAUST AIR 40 CFM</p>	<p>GUEST ROOM-30 1# 1.3 TR VRF BASED DUCTABLE UNIT SIZE:-900(W)x750(D)x300(H) FRESH AIR 30 CFM EXHAUST AIR 40 CFM</p>	<p>CORRIDOR 1# 1500 CFM 10.4 TR VRF BASED TFA UNIT SIZE:-1550(W)x1050(D)x620(H)</p>	

REV. NO.	DATE	DESCRIPTION
REVISIONS		

PROJECT	IIT KANPUR NOIDA EXTENSION CENTRE C-20/1A8, Sector-62, NOIDA		
TITLE	HVAC LAYOUT SIXTH FLOOR PLAN INNOVATION BLOCK		
DATE	DEALT GOUR	CHECKED VA	APPROVED UC
07.12.2018			
DRG. NO.	HVAC-08	REV. RD	SCALE 1:100