

COLUMN SCHEDULE

CONC. MIX	TOP OF FTG TO GROUND FLOOR ROOF M-25	GROUND FLOOR ROOF TO FIRST FLOOR ROOF M-25	FIRST FLOOR ROOF TO SECOND FLOOR ROOF M-25	SECOND FLOOR ROOF TO THIRD FLOOR ROOF M-25	THIRD FLOOR ROOF TO TERRACE M-25	RING SETS
C1(300X830)						
C2(300X830)						
C3(300X830)						
C4(300X600)						
C5(300X450)						
C6(300X600)						
C7(300X830)						
C8(300X600)						
C9(300X865)						
C10(300X830)						
C11(300X830)						
C12(300X300)						

- NOTES**
- ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SPECIFIED.
 - THE DRAWING SHOULD BE READ IN CONJUNCTION WITH RELEVANT ARCHITECTURAL DRAWING. ANY DISCREPANCY BETWEEN ARCH. DRAWING AND STRUCTURAL DRAWING SHALL BE RECONCILED BEFORE EXECUTION.
 - DULY WRITTEN DIMENSIONS ARE TO BE FOLLOWED. NEITHER THE BARS SHALL BE COUNTED NOR THE DIMENSION SCALED FROM DRAWINGS.
 - WATER FOR CONSTRUCTION PURPOSES SHALL CONFORM TO RELEVANT CLAUSES OF I.S. 456-2000.
 - BEARINGS FOR THE SLAB SHOULD BE PROVIDED FOR THE FULL WIDTH OF WALL UNLESS OTHERWISE SPECIFIED.
 - ALL REINFORCED CEMENT CONCRETE SHALL BE DESIGN MIX M-25 CONFORMING TO I.S.: 456-2000 STONE AGGREGATE SHALL BE 20 mm NOMINAL SIZE.
 - IN TWO WAY SLAB PLACE SHORT BARS IN BOTTOM LAYER.
 - ALL STEEL REINFORCEMENT SHALL BE OF TMT TYPE CONFORMING TO I.S.: 1786 AND HAVING MINIMUM YIELD STRENGTH OF 500N/mm²
 - LAP LENGTH/DEVELOPMENT LENGTH FOR REINFORCEMENT BARS AS/ I.S.: 456-2000 SHALL BE 40 X DIA OF BAR FOR M-25(UNLESS OTHERWISE SPECIFIED), LAPS SHALL BE STAGGERED AND AVOIDED AT THE POINT OF MAXIMUM BENDING MOMENT.
 - ALL BRICK IN THE MASONARY SHALL HAVE CHARACTERISTIC STRENGTH 7.5 N/mm² UNLESS OTHERWISE SPECIFIED AND LAID IN 1:6 (1 CEMENT : 6 SAND) MORTAR.
 - CLEAR COVER FOR:-
SLAB - 20mm
BEAM - 30mm
FOUNDATION - 50mm
COLUMNS - 40mm
 - LAP SHOULD NOT BE PROVIDED .
a) WITHIN A JOINT
b) WITHIN A DISTANCE 2 d FROM JOINT FACE.
c) WITHIN A DISTANCE 1/4 LENGTH OF MEMBER FROM THE JOINT FACE.
 - NOT MORE THAN 50% OF BAR SHALL BE SPLICED AT ONE SECTION.
 - THE REINFORCEMENT DETAILING SHALL BE AS PER IS: 13920.
 - CONSTRUCTION JOINT SHALL BE MADE VERTICAL BY PROPER TEMPLATE WITH SLOTS FOR ACCOMMODATING REINFORCEMENT BARS. THE JOINT SHALL BE TREATED IN ACCORDANCE WITH I.S 11817.
 - THE CONSTRUCTION JOINT SHALL BE PLANNED AND APPROVED BY THE ENGINEER IN CHARGE. BUT IT SHALL NOT BE PROVIDED IN BEAM.
 - EXPANSION JOINT SHALL BE AS PER DRAWING.

REVISIONS

NO.	DESCRIPTION	DATE	BY

ARCHITECTS
AKSHAYA JAIN & ASSOCIATES
 ARCHITECTURE. PLANNING. INTERIOR DESIGN
 C-6 / 6098, VASANT KUNJ, NEW DELHI - 110070
 TELEPHONES +91-11-26136098, 26132304, 41601615
 FAX +91-11-26132304 E-Mail : mail@akshayajain.com

STRUCTURAL CONSULTANT
SANRACHNA CONSULTANTS
 302 & 315, ANSAL'S MAJESTIC TOWER, PLOT NO.-17,
 BLOCK G-1, VIKAS PURI, NEW DELHI-110018
 PHONE:- 011-28545881,28543281
 E mail:- info@sanrachnaconsultants.com

PROJECT
**BUILDING FOR NATIONAL AEROSOL FACILITY
 & ACADEMIC ACTIVITES AT I.I.T KANPUR**

PROJECT NO.-	DRAWING NO. S-NN/TD-F3
SCALE	DRAWN- SUNIL PORIYA
DATE :-17-01-2015	CHECKED-SHARAD GUPTA

	DRAWING TITLE
	COLUMN SCHEDULE

TENDER DRAWING

NOTES :- NET SAFE BEARING CAPACITY IS 11.75 T/M. AT 2.0 M (ASSUMED)
 FINAL FOUNDATION DRAWING AFTER ISSUING THE SOIL REPORT