

**INDEX**

**Name of Work:**           **Construction of clean room facility in the ground floor of C block, Pre-Fab building near Old SAC at IIT Kanpur (SH: Air conditioning Works).**

<b>Sl. No.</b>	<b>Description</b>	<b>Page</b>
	<i>Index Page</i>	<b>1</b>
	<b>PART-A</b>	<b>2</b>
1	<i>E-Tender Notice and Information of e-Tendering for Contractors</i>	<b>3-12</b>
2	<i>Notice Inviting Tenders (Form CPWD-6)</i>	<b>13-17</b>
3	<i>Tender (Form CPWD-7)</i>	<b>18-23</b>
4	<i>Salient/Mandatory requirement for tender</i>	<b>24</b>
	<b>PART-B</b>	<b>25</b>
5	<i>General terms and conditions</i>	<b>26-27</b>
6	<i>Special Terms &amp; conditions</i>	<b>28-35</b>
7	<i>Technical Specifications</i>	<b>36-74</b>
8	<i>Special conditions for safety at work site</i>	<b>75-76</b>
9	<i>List of approved make</i>	<b>77-79</b>

**NIT amounting to Rs. 35,84,438/-- is approved.**

**[Certified that this N.I.T. contains 82 pages (Eighty Two Only).]**

***Executive Engineer***  
***I.W.D. Elect. & AC Divn.***  
***I.I.T., Kanpur***

***Superintending Engineer***  
***Central Office, I.W.D.***  
***I.I.T., Kanpur***

# ***PART-A***

**INDIAN INSTITUTE OF TECHNOLOGY KANPUR**  
**INSTITUTE WORKS DEPARTMENT**  
**Electrical & Air-conditioning Division**  
**E-TENDER NOTICE**

**NIT No. 31/AC/2019/359**

**dated: 10.12.2019**

The Superintending Engineer, IWD, I.I.T., Kanpur on behalf of Board of Governors of IIT Kanpur invites online item rate tenders for the following works from eligible air conditioning contractors for following air conditioning & refrigeration works:-

Sl. No	Name of work and location	Estimated cost put to tender (In Rs.)	Earnest Money (In Rs.)	Period of Completion (in Month)	Last date & time of submission of tender	Period during which EMD, Cost of Tender Document, e-Tender Processing Fee and other Documents shall be submitted	Time & date of opening of tender
1	<b>Construction of clean room facility in the ground floor of C block, Pre-Fab building near Old SAC at IIT Kanpur (SH: Air conditioning Works).</b>	35,84,438/-	71689/-	3	Upto 3:30 PM on 20.12.2019	After last date and time of submission of tender and upto 3:00 PM on 23.12.2019	At 3:30 PM on 26.12.2019

The E-tender documents is available on <http://eprocure.gov.in/eprocure/app>

*Acting Superintending Engineer*

Copy to :

1. Institute website: [www.iitk.ac.in/iwd/tenderhall.htm](http://www.iitk.ac.in/iwd/tenderhall.htm)
2. Notice Board

## **Information of e-Tendering for Contractors**

1. The intending tenderer must read the terms and conditions of FORM-6 for e-Tendering carefully. He should only submit his tender if he considers himself eligible and he is in possession of all the documents required.
2. Information and Instructions for tenderer posted on website shall form part of tender document.
3. The tender document consisting of plans, specifications, the schedule of quantities of various types of items to be executed and the set of terms and conditions of the contract to be complied with and other necessary documents can be seen and downloaded from website <https://eprocure.gov.in/eprocure/app> or [www.iitk.ac.in](http://www.iitk.ac.in) free of cost.
4. But the tender can only be submitted after uploading the mandatory scanned documents as per list given below.
5. Those contractors not registered on the website mentioned above, are required to get registered beforehand. If needed they can be imparted training on online bidding process as per details available on the website.

## BID DOCUMENT

Online bids (Technical & Financial) from eligible bidders which are valid for a period of 90 days from the date of Technical/financial Bid opening (i.e. 26.10.2019) are invited for and on behalf of the Superintending Engineer, IWD, IIT, Kanpur for "**Construction of clean room facility in the ground floor of C block, Pre-Fab building near Old SAC at IIT Kanpur (SH: Air conditioning Works).**"

Notice Inviting Tender No.	31/AC/2019/359 dated 10.12.2019
Name of Work	<b>Construction of clean room facility in the ground floor of C block, Pre-Fab building near Old SAC at IIT Kanpur (SH: Air conditioning Works).</b>
Estimated Cost	Rs.35,84,438/-
Earnest Money	Rs.71,689/-
<b>Date of Publishing</b>	<b>12.12.2019 (15:00 hrs)</b>
Clarification Start Date and Time	<b>12.12.2019 ( working days only)</b>
Clarification End Date and Time	<b>19.12.2019 ( working days only)</b>
Queries (if any)	No queries will be entertained after clarification end date and time
<b>Bid Submission Start Date</b>	<b>12.12.2019 (15:00 hrs)</b>
Last Date and time of uploading of Bids	<b>20.12.2019 (15.30 hrs)</b>
Last Date and time of <b>submitting</b> , EMD and other documents at IWD, IIT Kanpur	<b>23.12.2019 (15:30 hrs)</b>
Date and time of opening of Technical Bids	<b>23.12.2019 (16.00 hrs)</b>
Date and time of opening of Financial Bids	<b>26.12.2019 (15.30 hrs)</b>

Interested parties may view and download the tender document containing the detailed terms & conditions from the website <http://eprocure.gov.in/eprocure/app>

**(The bids have to be submitted online in electronic form on [www.eprocure.gov.in](http://www.eprocure.gov.in) only. No physical financial bids will be accepted.)**

## INSTRUCTION FOR ONLINE BID SUBMISSION

The bidders are required to submit soft copies of their bids electronically on the Central Public Procurement (CPP) Portal ie <http://eprocure.gov.in/eprocure/app> , using valid Digital Signature Certificates. The instructions given below are meant to assist the bidders in registering on the CPP Portal, prepare their bids in accordance with the requirements and submitting their bids online on the CPP Portal.

### **REGISTRATION**

- (i)** Bidders are required to enroll on the e-Procurement module of the Central Public Procurement Portal (URL:<https://eprocure.gov.in/eprocure/app>) by clicking on the link "Online Bidder Enrollment" option available on the home page. **Enrolment on the CPP Portal is free of charge.**
- (ii)** During enrolment/ registration, the bidders should provide the correct/ true information including valid email-id & mobile no. All the correspondence shall be made directly with the contractors/ bidders through email-id provided.
- (iii)** As part of the enrolment process, the bidders will be required to choose a unique username and assign a password for their accounts.
- (iv)** For e-tendering possession of valid Digital Signature Certificate (Class II or Class III Certificates with signing key usage) is mandatory which can be obtained from SIFY /nCode/eMudra or any Certifying Authority recognized by CCA India on eToken/ SmartCard.
- (v)** Upon enrolment on CPP Portal for e-tendering, the bidders shall register their valid Digital Signature Certificate with their profile.
- (vi)** Only one valid DSC should be registered by a bidder. Bidders are responsible to ensure that they do not lend their DSCs to others which may lead to misuse and should ensure safety of the same.
- (vii)** Bidders can then log into the site through the secured login by entering their userID/ password and the password of the DSC/ eToken.

### **SEARCHING FOR TENDER DOCUMENTS**

- 1) There are various search options built in the CPP Portal to facilitate bidders to search active tenders by several parameters. These parameters could include Tender ID, organization name, location, date, value, etc. There is also an option of advanced search for tenders, wherein the bidders may combine a number of search parameters such as organization name,

form of contract, location, date, other keywords, etc., to search for a tender published on the CPP Portal.

- 2) Once the bidders have selected the tenders they are interested in, they may download the required documents / tender schedules. These tenders can be moved to the respective 'My Tenders' folder. This would enable the CPP Portal to intimate the bidders through SMS / e-mail in case there is any corrigendum issued to the tender document.
- 3) The bidder should make a note of the unique Tender ID assigned to each tender, in case they want to obtain any clarification / help from the Helpdesk.

#### **PREPARATION OF BIDS:**

- (i) For preparation of bid Bidders shall search the tender from published tender list available on site and download the complete tender document and should take into account corrigendum if any published before submitting their bids.

After selecting the tender document same shall be moved to the 'My favourite' folder of bidders account from where bidder can view all the details of the tender document.

- (ii) Bidder shall go through the tender document carefully to understand the documents required to be submitted as part of the bid. Bidders shall note the number of covers in which the bid documents have to be submitted, the number of documents – including the names and content of each of the document that need to be submitted. Any deviations from these may lead to rejection of the bid.
- (iii) Any pre-bid clarifications if required, then same may be obtained online through the tender site, or through the contact details given in the tender document.
- (iv) Bidders should get ready in advance the bid documents in the required format (PDF/xls/rar/jpg formats) to be submitted as indicated in the tender document/schedule. **Bid documents may be scanned with 100 dpi with black and white option which helps in reducing size of the scanned document.**
- (v) Bidders can update well in advance, the documents such as experience certificates, annual report, PAN, EPF & other details etc., under "My Space/ Other Important Document" option, which can be submitted as per tender requirements. This will facilitate the bid submission process faster by reducing upload time of bids.

#### **SUBMISSION OF BIDS:**

- (i) Bidder should log into the site well in advance for bid submission so that he/ she upload the bid in time i.e. on or before the bid submission time. Bidder will be responsible for any delay.

- (ii) Bidder should prepare the EMD as per the instructions specified in the NIT/ tender document. The details of the DD/BC/BG/ others physically sent, should tally with the details available in the scanned copy and the data entered during bid submission time. Otherwise the uploaded bid will be rejected.*
- (iii) While submitting the bids online, the bidder shall read the terms & conditions (of CPP portal) and accepts the same in order to proceed further to submit their bid.*
- (iv) Bidders shall select the payment option as offline to pay the EMD and enter details of the DD/BC/BG/others. The intending tenderer has to fill all the details such as Banker's name, Demand Draft/Fixed Deposit Receipt /Pay Order/ Banker's Cheque/Bank Guarantee number, amount and date.*
- (v) The amount of EMD can be paid by multiple Demand Draft / Pay Order / Banker's Cheque / Deposit at call receipt / Fixed Deposit Receipts along with multiple Bank Guarantee of any Scheduled Bank.*
- (vi) Bidder shall digitally sign and upload the required bid documents one by one as indicated in the tender document.*
- (vii) Bidders shall note that the very act of using DSC for downloading the tender document and uploading their offers is deemed to be a confirmation that they have read all sections and pages of the tender document without any exception and have understood the complete tender document and are clear about the requirements of the tender document.*
- (viii) Bid documents may be scanned with 100 dpi with black and white option which helps in reducing size of the scanned document. For the file size of less than 1 MB, the transaction uploading time will be very fast.*
- (ix) If price quotes are required in XLS format, utmost care shall be taken for uploading Schedule of quantities & Prices and any change/ modification of the price schedule shall render it unfit for bidding.*

*Bidders shall download the Schedule of Quantities & Prices i.e. Schedule-A, in XLS format and save it without changing the name of the file. Bidder shall quote their rate in figures in the appropriate cells, thereafter save and upload the file in financial bid cover (Price bid) only.*

*If the template of Schedule of Quantities & Prices file is found to be modified/corrupted in the eventuality by the bidder, the bid will be rejected and further dealt as per provision of clause no 23.0 of ITB including forfeiture of EMD.*



***The bidders are cautioned that uploading of financial bid elsewhere i.e. other than in cover 2 will result in rejection of the tender.***

- (x) Bidders shall submit their bids through online e-tendering system to the Tender Inviting Authority (TIA) well before the bid submission end date & time (as per Server System Clock). The TIA will not be held responsible for any sort of delay or the difficulties faced during the submission of bids online by the bidders at the eleventh hour.***
- (xi) After the bid submission (i.e. after Clicking “Freeze Bid Submission” in the portal), the bidders shall take print out of system generated acknowledgement number and keep it as a record of evidence for online submission of bid, which will also act as an entry pass to participate in the bid opening.***
- (xii) Bidders should follow the server time being displayed on bidder’s dashboard at the top of the tender site, which shall be considered valid for all actions of requesting, bid submission, bid opening etc., in the e-tender system.***
- (xiii) All the documents being submitted by the bidders would be encrypted using PKI (Public Key Infrastructure) encryption techniques to ensure the secrecy of the data. The data entered cannot be viewed by unauthorized persons until the time of bid opening. The confidentiality of the bids is maintained using the secured Socket Layer 128 bit encryption technology.***

**ASSISTANCE TO BIDDERS:**

- (i) Any queries relating to the tender document and the terms and conditions contained therein should be addressed to the Tender Inviting Authority for a tender or the relevant contract person indicated in the tender. The contact number for the helpdesk is 0512-2597416 between 10:30 hrs to 17:00 hrs.***
- (ii) Any queries relating to the process of online bid submission or queries relating to CPP Portal in general may be directed to the 24X7 CPP Portal Helpdesk. The 24 x 7 Help Desk Number 0120-4200462, 0120-4001002 and 0120-4001005. The helpdesk email id is [support-eproc@nic.in](mailto:support-eproc@nic.in)***

## INSTRUCTION FOR e-PROCUREMENT

### 1. PREPARATION AND SUBMISSION OF BIDS :

- a. The detailed tender documents may be downloaded from <http://eprocure.gov.in/eprocure/app> till the last date of submission of tender. The Tender may be submitted online through CPP Portal <http://eprocure.gov.in/eprocure/app>
- b. The bidder should submit the bid online in two parts viz. Technical Bid and Financial Bid. Technical Bid should be upload online in cover- 1 and Financial Bid in “.Xls” should be upload online in cover-2

### 2. SUBMISSION OF THE BID : All interested eligible bidders are requested to submit their bids online on CPP Portal: <http://eprocure.gov.in/eprocure/app> as per the criteria given in this document:

- a. Technical Bid should be upload online in cover-1.
- b. Financial Bid should be upload online in cover-2

Both Technical and Financial Bid covers should be placed online on the CPP Portal (<http://eprocure.gov.in/eprocure/app> ).

### 3. TECHNICAL BID: Signed and Scanned copies of the Technical bid documents as under must be submitted online on CPP Portal: <http://eprocure.gov.in/eprocure/app> .

**List of Documents to be scanned and uploaded (Under Cover-1) within the period of bid submission:-**

- Copy of Registration with the Department if any or specialized agencies.
- Required experience / completion certificates of similar nature of works. The works certificates submitted by the bidder clearly indicate that:
  1. The completion certificate of the air-conditioning & refrigeration works
  2. Actual date of completion of the above air-conditioning work.
- Copy of EPF & ESI No.
- Copy of GST Registration No.
- Details of turn over during the last three years.
- Copy of bank solvency certificate
- Scan copy of E.M.D. as to be submitted in hard copy.

*The hardcopy of above documents alongwith earnest money deposit receipt shall be submitted in the office of Executive Engineer (AC), Central Office, IWD within last date and time of submission as specified in the above bid document.*

*Please note that no indication of the rates/amounts be made in any of the documents submitted with the TC-BID.*

#### **4. Financial Bid**

- a. The currency of all quoted rates shall be Indian Rupees. All payment shall be made in Indian Rupees.*
- b. In preparing the financial bids, bidders are expected to take into account the requirements and conditions laid down in this Tender document. The financial bids should be uploaded online as per the specified “.Xls” format i.e. Price Bid in Excel sheet attached as ‘.Xls’ with the tender and based on the scope of work, service conditions and other terms of the Tender document. It should include all costs associated with the Terms of Reference/Scope of Work of the assignment.*
- c. Being an individual work contract no other tax is payable other than GST. The GST shall be paid extra as applicable.*

#### **5. Last Date for Submission of Tender:**

- a. Online bids complete in all respects, must be submitted on or before the last date and time specified in the schedule of events.*
- b. The IIT, Kanpur may, at its own discretion, alter/extend the last date for submission of tenders.*

#### **6. Bid Validity**

- a. All the Bids must be valid for a period of 90 days from the last date of submission of the tender for execution of Contract. However, the quoted rates should be valid for the initial/ extended period of the Contract from the effective date of the Contract. No request will be considered for price revision during the original Contract period.*
- b. A bid valid for a shorter period shall be declared as non-responsive.*
- c. In exceptional circumstances, prior to expiry of the original time limit, the IIT may request the bidders to extend the period of validity for a specified additional period beyond the original validity of 90 days. The request and the bidders' responses shall be made in writing. The bidders, not agreeing for such extensions will be allowed to withdraw their bids without forfeiture of their Bid Security.*

#### **7. Modification/ Substitution/ Withdrawal of bids:**

- a. No Bid shall be modified, substituted or withdrawn by the Bidder after the Bid 's due Date.*

*b. Any alteration/ modification in the Bid or additional information supplied subsequent to the Bid's due Date, unless the same has been expressly sought for by the Authority, shall be disregarded.*

**8. Rejection of the Bid:** *The bid submitted shall become invalid if:-*

- a) The tenderer is found ineligible.*
- b) The tenderer does not upload all the documents as stipulated in the tender document.*
- c) If any discrepancy is noticed between the documents as uploaded at the time of submission of tender and hard copies as submitted physically in the office of tender opening authority.*

## NOTICE INVITING TENDER (FORM -6 FOR E-Tendering)

The Executive Engineer, IWD, I.I.T., Kanpur on behalf of Board of Governors of IIT Kanpur invites online item rate tenders from eligible air conditioning contractor for the following work(s): **Construction of clean room facility in the ground floor of C block, Pre-Fab building near Old SAC at IIT Kanpur (SH: Air conditioning Works)..**

1.1 *The work is estimated to cost Rs. 35,84,438/-. This estimate, however, is given merely as a rough guide.*

### 2 **Criteria of eligibility**

1. *The eligible specialized agencies of clean rooms.*
2. *Having satisfactorily completed 3 (three) similar works each of value 40% of the estimated cost or two similar works each of value 60% of the estimated cost or one similar work of value 80% of estimated cost during last seven years. Out of the above at least one work must be in the Central Govt. /Central autonomous bodies/central PSU/State PSU/State Govt.*
3. *Similar nature of work means: Having executed works of clean rooms of at least Clean Class10000 capacity consisting of Supply, installation, testing & commissioning of AHU, ducting, CHW piping, paneling, HEPA filter and its associated controls etc.*
4. *Having GST, ESI & EPF registration No. of government authorities.*
5. *Details of average annual financial turnover of air-conditioning works should be at least 100% of the estimated cost during the last 3 consecutive financial years.*
6. *Having a bank solvency certificate of not less of 40% of estimated cost.*
3. *Agreement shall be drawn with the successful tenderers on prescribed Form No. CPWD 7 (or other Standard Form as mentioned) which is available as a Govt. of India Publication and also available on website [www.iitk.ac.in](http://www.iitk.ac.in) Tenderers shall quote his rates as per various terms and conditions of the said form which will form part of the agreement.*
4. *The time allowed for carrying out the work will be 3 Months from the date of start as defined in schedule 'F' or from the first date of handing over of the site, whichever is later, in accordance with the phasing, if any, indicated in the tender documents.*
5. *The site for the work is available.\**
6. *The tender document consisting of plans, specifications, the schedule of quantities of various types of items to be executed and the set of terms and conditions of the contract to be complied with and other necessary documents except Standard General Conditions of Contract Form can be seen on website <http://eprocure.gov.in/eprocure/app> or [www.iitk.ac.in](http://www.iitk.ac.in) other necessary documents also can be seen in the office of the EE, Electrical and Air conditioning Division, IWD, IIT, Kanpur between hours of 3.00 PM to 3:00 PM from 12.12.2019 to 20.12.2019 free of cost.*
7. *After submission of the tender the contractor can re-submit revised tender any number of times but before last time and date of submission of tender as notified.*
8. *While submitting the revised tender, contractor can revise the rate of one or more item(s) any number of times (he need not re-enter rate of all the items) but before last time and date of submission of tender as notified.*

9. *When tenders are invited in three stage system and if it is desired to submit revised financial tender then it shall be mandatory to submit revised financial tender. If not submitted then the tender submitted earlier shall become invalid.*
10. *Earnest Money can be paid in the form of Treasury Challan or Demand Draft or Pay order or Banker`s Cheque or Deposit at Call Receipt or Fixed Deposit Receipt (drawn in favour of **Director, IIT, Kanpur** along with Bank Guarantee of any Scheduled Bank wherever applicable.*

*A part of earnest money is acceptable in the form of bank guarantee also. In such case, 50% of earnest money or Rs. 20 lac, whichever is less, will have to be deposited in shape prescribed above, and balance in shape of Bank Guarantee of any scheduled bank.*

*Treasury Challan or Demand Draft or Pay Order or Banker`s Cheque or Deposit at Call Receipt or FDR or Bank Guarantee against EMD, Cost of Tender Document and Cost of Tender Processing Fee shall be placed in single sealed envelope superscripted as “Earnest Money, Cost of Tender Document and Cost of Tender Processing Fee” with name of work and due date of opening of the tender also mentioned thereon.*

*Copy of Enlistment Order and certificate of work experience wherever applicable and other documents if required and specified in this bid document shall be scanned and uploaded to the e-Tendering website within the period of tender submission and certified copy of each shall be deposited in a separate envelop marked as “Other Documents”.*

*Both the envelopes shall be placed in another envelope with due mention of Name of work, date & time of opening of tenders and to be submitted in the office of Superintending Engineer after last date & time of submission of tender and up to 03:30 PM **on 23.12.2019**. The documents submitted shall be opened at 04:00 PM on **23.12.2019**.*

*Online tender documents submitted by intending tenderers shall be opened only of those tenderers, whose Earnest Money Deposit, Cost of Tender Document and e- Tender Processing Fee and other documents placed in the envelope are found in order.*

*The tender submitted shall be opened at 03:30 PM on **26.12.2019**.*

11. *The tender submitted shall become invalid and cost of tender & e-Tender processing fee shall not be refunded if:*
- (i) *The tenderers is found ineligible.*
  - (ii) *The tenderers does not upload all the documents as stipulated in the tender document.*
  - (iii) *If any discrepancy is noticed between the documents as uploaded at the time of submission of tender and hard copies as submitted physically in the office of tender opening authority.*
12. *The contractor whose tender is accepted will be required to furnish performance guarantee of 5% (Five Percent) of the tendered amount within the period specified in Schedule F. This guarantee shall be in the form of cash (in case guarantee amount is less than 10000/-) or Deposit at Call receipt of any scheduled bank/Banker`s cheque of any scheduled bank/Demand Draft of any scheduled bank/Pay order of any Scheduled Bank of any scheduled bank (in case guarantee amount is less than ` 1,00,000/-) or Government Securities or Fixed Deposit Receipts or Guarantee Bonds of any Scheduled Bank or the State Bank of India in accordance with the prescribed form. **In case the contractor fails to deposit the said performance guarantee within the period as indicated in Schedule ‘F’, including the extended period if any, the***

***Earnest Money deposited by the contractor shall be forfeited automatically without any notice to the contractor.***

13. *Intending Tenderers are advised to inspect and examine the site and its surroundings and satisfy themselves before submitting their tenders as to the nature of the ground and sub-soil (so far as is practicable), the form and nature of the site, the means of access to the site, the accommodation they may require and in general shall themselves obtain all necessary information as to risks, contingencies and other circumstances which may influence or affect their tender. A tenderers shall be deemed to have full knowledge of the site whether he inspects it or not and no extra charge consequent on any misunderstanding or otherwise shall be allowed. The tenderers shall be responsible for arranging and maintaining at his own cost all materials, tools, & plants, water, electricity access, facilities for workers, and all other services required for executing the work unless otherwise specifically provided for in the contract documents. Submission of a tender by a tenderer implies that he has read this notice and all other contract documents and has made himself aware of the scope and specifications of the work and local conditions and other factors having a bearing on the execution of the work.*
14. *The competent authority on behalf of the Board of Governors, IIT, Kanpur does not bind itself to accept the lowest or any other tender and reserves to itself the authority to reject any or all the tenders received without the assignment of any reason. All tenders in which any of the prescribed condition is not fulfilled or any condition including that of conditional rebate is put forth by the tenderers shall be summarily rejected.*
15. *Canvassing whether directly or indirectly, in connection with tenderers is strictly prohibited and the tenders submitted by the contractors who resort to canvassing will be liable for rejection.*
16. *The competent authority on behalf of Board of Governors, IIT, Kanpur reserves to himself the right of accepting the whole or any part of the tender and the tenderers shall be bound to perform the same at the rate quoted.*
17. *The contractor shall not be permitted to tender for works in the IIT Kanpur responsible for award and execution of contracts, in which his near relative is posted a Divisional Accountant or as an officer in any capacity between the grades of Superintending Engineer and Junior Engineer (both inclusive). He shall also intimate the names of persons who are working with him in any capacity or are subsequently employed by him and who are near relatives to any gazetted officer in the IIT Kanpur. Any breach of this condition by the contractor would render him liable to be removed from the approved list of contractors of this Department.*
18. *No Engineer of Gazetted Rank or other Gazetted Officer employed in Engineering or Administrative duties in an Engineering Department of the Government of India is allowed to work as a contractor for a period of one year after his retirement from Government service, without the prior permission of the Government of India in writing. This contract is liable to be cancelled if either the contractor or any of his employees is found any time to be such a person who had not obtained the permission of the Government of India as aforesaid before submission of the tender or engagement in the contractor's service.*
19. *The tender for the works shall remain open for acceptance for a period of **ninety (90) days** from the date of opening of tenders if any tenderer withdraws his tender before the said period or issue of letter of acceptance, whichever is earlier, or makes any modifications in*

*the terms and conditions of the tender which are not acceptable to the department, then the Government shall, without prejudice to any other right or remedy, be at liberty to forfeit 50% of the said earnest money as aforesaid. Further the tenderers shall not be allowed to participate in the retendering process of the work.*

20. *This Notice Inviting Tender shall form a part of the contract document. The successful tenderers/contractor, on acceptance of his tender by the Accepting Authority shall within 15 days from the stipulated date of start of the work, sign the contract consisting of:-*

a) *The Notice Inviting Tender, all the documents including additional conditions, specifications and drawings, if any, forming part of the tender as uploaded at the time of invitation of tender and the rates quoted online at the time of submission of tender and acceptance thereof together with any correspondence leading thereto.*

b) *Standard C.P.W.D. Form 7 or other Standard C.P.W.D. Form as applicable.*

20.1.1 *The tender document will include following three components:*

**Part A:-**

*CPWD-6, CPWD-7 including schedule A to F for the major component of the work, Standard General Conditions of Contract for CPWD 2014 as amended/modified up to **20.12.2019.***

**Part B:-**

*General/specific conditions, specifications and schedule of quantities applicable to major component of the work.*

**Part C:-**

*Schedule A to F for minor component of the work. (SE/EE in charge of major component shall also be competent authority under clause 2 and clause 5 as mentioned in schedule A to F for major components), General/specific conditions, specifications and schedule of quantities applicable to minor component(s) of the work.*

20.1.2 *The tenderers must associate himself, with agencies of the appropriate class eligible to tender for each of the minor component individually.*

20.1.3 *The eligible tenderers shall quote rates for all items of major component as well as for all items of minor components of work.*

20.1.4 *Entire work under the scope of composite tender including major and all minor components shall be executed under one agreement.*

20.1.5 *Security Deposit will be worked out separately for each component corresponding to the estimated cost of the respective component of works. The Earnest Money will become part of the security deposit of the major components of work.*



21. *The EPF & ESI contribution deposited against the contract workers shall be reimbursed on actual basis.*

*Executive Engineer  
For & on behalf of the Board of Governors, IIT, Kanpur*

**ITEM RATE TENDER AND CONTRACT FOR WORK**

- (A) **Tender for the work of:** | **Construction of clean room facility in the ground floor of C block, Pre-Fab building near Old SAC at IIT Kanpur (SH: Air conditioning Works).**

**TENDER**

I/We have read and examined the Notice Inviting tender, schedule, A,B,C,D,E&F. Specifications applicable, Drawings & Designs, General Rules and Directions, Conditions of Contract, clauses of contract, Special conditions, Schedule of Rate & other documents and rules referred to in the conditions of contract and all other contents in the tender document for the work.

*I/We hereby tender for the execution of the work specified for the Board of Governors, IIT, Kanpur within the time specified in Schedule 'F', viz., schedule of quantities and in accordance in all respects with the specifications, designs, drawings and instructions in writing referred to in Rule-1 of General Rules and Directions and in Clause 11 of the Conditions of contract and with such materials as are provided for, by, and in respects in accordance with, such conditions so far as applicable.*

*We agree to keep the tender **open for (90) ninety days from the date of opening of tender** and not to make any modifications in its terms and conditions.*

*A sum of Rs. **71,689.00** is hereby forwarded in Cash/Receipt Treasury Challan/Deposit at call Receipt of a Scheduled Bank/Fixed deposit receipt of scheduled bank/demand draft of a scheduled bank/bank guarantee issued by scheduled bank as earnest money. If I/we, fail to furnish the prescribed performance guarantee or fail to commence the work within prescribed period I/we agree that the said Board of Governors, IIT, Kanpur or his successors in office shall without prejudice to any other right or remedy be at liberty to forfeit the said earnest money absolutely. Further, if I/we fail of commence work as specified, I/we agree that Board of Governors, IIT, Kanpur or his successors in office shall without prejudice to any other right or remedy available in law, be at liberty to forfeit the said earnest money and the performance guarantee absolutely, otherwise the said earnest money shall be retained by him towards security deposit to execute all the works referred to in the tender documents upon the terms and conditions contained or referred to therein and to carry out such deviations as may be ordered, up to maximum of the percentage mentioned in Schedule 'F' and those in excess of that limit at the rates to be determined in accordance with the provision contained in Clause 12.2 and 12.3 of the tender form.*

*Further, I/We agree that in case of forfeiture of earnest money or both Earnest Money & Performance Guarantee as aforesaid, I/We shall be debarred for participation in the re-tendering process of the work.*

*I/We undertake and confirm that eligible similar work(s) has/ have not been got executed through another contractor on back to back basis. Further that, if such a violation comes to the notice of Department, then I/we shall be debarred for tendering in IIT, Kanpur in*

*future forever. Also, if such a violation comes to the notice of Department before date of start of work, the Engineer-in-Charge shall be free to forfeit the entire amount of Earnest Money Deposit/Performance Guarantee.*

*I/We hereby declare that I/we shall treat the tender documents drawings and other records connected with the work as secret/confidential documents and shall not communicate information derived there from to any person other than a person to whom I/we am/are authorized to communicate the same or use the information in any manner prejudicial to the safety of the State.*

*Dated \_\_\_\_\_ \*\* \_\_\_\_\_*

*Witness: \*\**

*Address: \*\**

*Occupation: \*\**

*\*\**

*Signature of contractor*

*Postal Address \*\**

# ACCEPTANCE

The above tender (as modified by you as provided in the letters mentioned hereunder) is accepted by me for and on behalf of the Board of Governors, IIT, Kanpur for a sum of Rs. \_\_\_\_\_ (Rupees \_\_\_\_\_)

*The letters referred to below shall form part of this contract Agreement:-*

- a) \_\_\_\_\_
- b) \_\_\_\_\_
- c) \_\_\_\_\_

*For & on behalf of the Board of Governors,  
IIT, Kanpur*

*Dated* \_\_\_\_\_

*Signature* \_\_\_\_\_  
*Designation* \_\_\_\_\_

**Operative schedules shall be supplied separately to each intending tenderer**

**SCHEDULE 'A'**

*Schedule of Quantities:*

**SCHEDULE 'B'**

*Schedule of materials to be issued to the contractor:*

<i>S. No.</i>	<i>Description of item</i>	<i>Quantity</i>	<i>Rates in figures &amp; words at which the material will be charged to the contractor</i>	<i>Place of issue</i>
<i>1</i>	<i>2</i>	<i>3</i>	<i>4</i>	<i>5</i>
<b>-----NIL-----</b>				

**SCHEDULE 'C'**

*Schedule of Tools and Plants to be hired to the contractor*

<i>S. No.</i>	<i>Description</i>	<i>Hire charges per day</i>	<i>Place of issue</i>
<i>1</i>	<i>2</i>	<i>3</i>	<i>4</i>
<b>-----NIL-----</b>			

**SCHEDULE 'D'**

*Extra schedule for specific requirements/document for the work, if any:* **As attached in tender form.**

**SCHEDULE 'E'**

Schedule of component of other Materials, Labour, POL etc. for price escalation: **N.A.**

**SCHEDULE 'F'**

Reference to General Conditions of contract.

<b>Name of Work:</b>	<b>Construction of clean room facility in the ground floor of C block, Pre-Fab building near Old SAC at IIT Kanpur (SH: Air conditioning Works).</b>	
<b>Estimated cost of the work:</b>	Air-conditioning Items of Work	<b>Rs.35,84,438/-</b>
<b>Earnest money</b>		<b>Rs.71,689/-</b>
<b>Performance Guarantee</b>	5% of the tendered value of the work	
<b>Security Deposit</b>	5% of the tendered value of the work	

**General rules and direction:**

**Definitions:**

2(v)	<b>Engineer-in-Charge</b>  For Air-conditioning & Refrigeration/Electrical items of work	<b>Executive Engineer, Institute Works Department IIT, Kanpur</b>
2(vi)	Accepting Authority	<b>Superintending Engineer, Institute Works Department IIT, Kanpur</b>
2(vii)	Percentage on cost of materials and labour to cover all overheads and profits	15%
2(viii)	<b>Standard Schedule of Rates:</b>  Electrical Items of Work:	D.S.R. 2018 with up to date correction slips
2(ix)	Department:	Central Public Works Department
2(x)	Standard CPWD contract Form:	GCC 2014, CPWD <b>form-7</b> as modified & corrected up to <b>20.12.2019</b> (Whether correction vide latest circulars are incorporated or not in this document).
<b>Clause 1</b>	i) Time allowed for submission of Performance Guarantee from the date of issue of letter of acceptance	15 Days
	ii) Maximum allowable extension beyond the period as provided in i) above	7 Days
<b>Clause 2</b>	Authority for fixing Compensation under Clause 2	<b>Superintending Engineer, Institute Works Department IIT, Kanpur. Or successor thereof</b>
<b>Clause 2 A</b>	Whether Clause 2A shall be applicable	No
<b>Clause 5</b>	i) Number of days from the date of issue of letter of acceptance for reckoning date of start	22 Days
	ii) Time allowed for execution of work	<b>3(Three) Months</b>

<i>Authority to decide</i>	<i>Extension of time</i>	<i>Superintending Engineer, Institute Works Department IIT, Kanpur</i>
----------------------------	--------------------------	--

**Clause 6/ 6A**

**Only clause 6 applicable.**

**Clause 7**

*Gross work to be done together with net payment/Adjustment of advances for material collected, if any, since the last such payment for being eligible to interim payment*

**Not applicable**

**Clause 10A**

*Material to be provided by the contractor.*

**Applicable**

**Clause 10B (ii), (iii)**

*Whether clause 10-B (ii) and 10-B (iii) shall be applicable.*

**Not Applicable**

**Clause 10 C**

*Component of labour expressed as percentage of value of work*

**Not applicable**

**Clause 10 CA**

*Materials covered under this clause.*

**Nearest material (other than cement, reinforcement bars and structural steel) for which All India Whole sale price Index is to be followed.**

**Base price of all the materials covered under clause 10 CA**

*1. Cement (PPC)*

**Nil**

**NIL**

*2. Steel*

**Nil**

**Nil**

**Clause 10 CC**

*Increase/Decrease in Price of materials/wages*

**Not Applicable**

**Clause 11**

**Specification to be followed for execution of work:**

**For electrical works**

**CPWD specifications 2013 internal and 2013 external electrical works**

**For Air conditioning & Refrigeration item of works**

**CPWD Specifications 2017 HVAC for Air-conditioning & refrigeration works with up to date correction slips. (Hereinafter called CPWD specifications also)**

**Clause 12**

**12.2 & 12.3**

*Deviation limit beyond which clause 12.2 & 12.3 shall apply for building work*

**---**

**Clause 16**

**Competent Authority for Deciding reduced rates:**

*For electrical/civil/Air-conditioning & refrigeration items of work*

**Superintending Engineer,  
Institute Works Department  
IIT, Kanpur**

**Clause 18**

*List of mandatory machinery, tools & plants to be deployed by the contractor at site.*

**Ladders, Multi-meter, drill machine, crimping tools, spanner set, blower, Gas Charging line with equipment, welding torch etc**

**Clause 36 (i)**

**Requirement of technical Representative(s)**

**Requirement of technical Representative(s)**

**Requirement of Technical Representative (S) and recovery Rate**

Sl. No.	Minimum Qualification of Technical Representative	Discipline	Designation (Principal Technical / Technical representative)	Minimum Experience	Number	Rate at which recovery shall be made from the contractor in the event of not fulfilling provision of clause 36(i)	
						Figures	Words
1.	B.E./B.Tech	Electrical / mechanical	Graduate Engineer	5	1	Rs.21,000/- p.m	Twenty One Thousand per month

*For supervision of air-conditioning as well as electrical items of work, technical representatives of the respective disciplines will be required to be deployed.*



# SALIENT/MANDATORY REQUIREMENTS FOR THE TENDER

**Name of Work:** **Construction of clean room facility in the ground floor of C block, Pre-Fab building near Old SAC at IIT Kanpur (SH: Air conditioning Works).**

- 1 *The tenderer is advised to read and examine the tender documents for the work and the set of drawings available with Engineer-in-charge. He should inspect and examine the site and its surroundings by himself before submitting his tender.*
- 2 *Separate schedule of quantity is included in this tender for air conditioning & refrigeration items of work. If the tenderer wants to offer any unconditional rebates on their rates, the same should also be offered in the respective components of schedule separately. The contractor shall quote the item rates in figures and words accurately so that there is no discrepancy in rates written in figures and words.*
- 3 *Time allowed for the execution of work is 3(Three) months.*
- 4 *The contractor(s) shall submit a detailed program of execution in accordance with the master programme/milestone within ten days from the date of issue of award letter.*
- 5 *Contractor has to arrange and install field laboratory during the currency of work and nothing extra will be paid on this account.*
- 6 *Quality of the project is of utmost importance. This shall be adhered to in accordance with the provisions of CPWD specifications and guidelines given in the relevant paras.*
- 7 *Contractor has to deploy required Plant and machinery on the project. In case the contractor fails to deploy the plant and machinery whenever required and as per the direction of the Engineer-in-charge, he (Engineer-in-charge) shall be at a liberty to get the same deployed at the risk and cost of the contractor.*
- 8 *The contractor shall comply with the provisions of the Apprentices Act 1961, and the rules and orders issued there under from time to time. If he fails to do so, his failure will be a breach of the contract and the Superintending Engineer/Executive Engineer may in his discretion, without prejudice to any other right or remedy available in law, cancel the contract. The contractor shall also be liable for any pecuniary liability arising on account of any violation by him of the provisions of the said Act.*
- 9 *Electricity and water services will be provided by the institute free of cost on the request of the contractor.*

# ***PART-B***

## GENERAL TERMS AND CONDITIONS

- 1 *Unless otherwise provided in the Schedule of Quantities/Specifications, the rates tendered by the contractor shall be all inclusive and shall apply to all heights, lifts, leads and depths of the work and nothing extra shall be payable to him on account of the same. Extra payment for centering/shuttering, if required to be done for heights greater than 3.5 m shall however be admissible at the rates arrived at in accordance with clause 12 of the agreement, if not already specified.*
- 2 Other agencies doing works related with this project may also simultaneously execute their works and the contractor shall afford necessary facilities for the same. The contractor shall leave such necessary holes, openings etc. for laying/burying in the work, pipes cables, conduits, clamps, boxes and hooks for fan clamps etc. as may be required for the other agencies. Nothing extra over the Agreement rates shall be paid for doing these.
- 3 Some restrictions may be imposed by the security staff etc. on the working and for movement of labour, materials etc. The contractor shall be bound to follow all such restrictions/instructions and nothing extra shall be payable on account of the same.
- 5.1 *The contractor shall fully comply with all legal orders and directions of the Public or local authorities or municipality and abide by their rules and regulations and pay all fees and charges for which he may be liable in this regard. Nothing extra shall be paid/reimbursed for the same.*
- 5.2 *The building work shall be carried out in the manner complying in all respects with the requirements of the relevant bylaws and regulations of the local body under the jurisdiction of which the work is to be executed or as directed by the Engineer-in-charge and nothing extra shall be paid on this account.*
- 6 If as per local Municipal regulations, huts for labour are not to be erected at the site of work; the contractor shall be required to provide such accommodation at a place as is acceptable to the local body and nothing extra shall be paid on this account.
- 7 The structural and architectural drawings shall at all times be properly co-related before executing any work. However, in case of any discrepancy in the item given in the schedule of quantities appended with the tender and Architectural drawings relating to the relevant item, the former shall prevail unless otherwise given in writing by the Engineer-in-charge.
- 8.1 For the purpose of recording measurements and preparing running account bills, the abbreviated nomenclature indicated in the publications Abbreviated Nomenclature of Items of DSR 2014 shall be accepted. The abbreviated nomenclature shall be taken to cover all the materials and operations as per the complete nomenclature of the relevant items in the agreement and relevant specifications.
- 8.2 In case of items for which abbreviated nomenclature is not available in the aforesaid publication and also in case of extra and substituted items for which abbreviated nomenclature are not provided for in the agreement, full nomenclature of item shall be reproduced in the measurement books and bill forms for running account bills.
- 8.3 For the final bill, however, full nomenclature of all the items shall be adopted in preparing abstract in the measurement books and in the bill forms.
- 9 *The contractor shall take instructions from the Engineer-in-charge for stacking of materials. No excavated earth or building materials etc. shall be stacked/collected in areas where other buildings, roads, services, compound walls etc. are to be constructed.*

- 10 *Any trenching and digging for laying sewer lines/water lines/cables etc. shall be commenced by the contractor only when all men, machinery's and materials have been arranged and closing of the trench(s) thereafter shall be ensured within the least possible time.*
- 11 *It shall be ensured by the contractor that no electric live wire is left exposed or unattended to avoid any accidents in this regard.*
- 12 *In case the supply of timber/steel frames/shutters for doors, windows etc. is made by some other agency, the contractor shall make necessary arrangements for their safe custody on the direction of the Engineer-in-charge till the same are fixed in position by him & nothing extra shall be paid on this account.*
- 13 *The contractor shall maintain in perfect condition, all portions executed till completion of the entire work allotted to him. Where however phased delivery of work is contemplated these provisions shall apply separately to each phase.*
- 14 *The entire royalty at the prevalent rates shall have to be paid by the contractor on all the boulders, metals, shingle sand etc. collected by him for execution of the work, directly to the Revenue authority or authorized agents of the State Government concerned, or the Central Government, as the case may be.*
- 15.1 *The contractor shall bear all incidental charges for cartage, storage and safe custody of materials issued by the departments and shall construct suitable godowns, yards at the site of work for storing all materials as to be safe against damage by sun, rain, dampness, fire, theft etc. at his own cost and also employ necessary watch and ward establishment for the purpose, at his own cost. Materials to be charged directly to work and stipulated for issue free of cost shall also be issued to the contractor as soon as those are received at site or at the stipulated place of issue. The provision of this para shall apply equally and fully to those as well.*
- 15.2 *All materials obtained from the Institute Works Department store or otherwise on receipt shall be got checked by the Engineer-in-charge of the work or his representations before use.*
- 15.3 *Registers for the materials to be issued by the department shall be maintained as required by the Engineer-in-charge and these shall be signed by the contractor or his authorized agent and representative of Engineer-in-charge on each day of transactions.*

## ***SPECIAL TERMS & CONDITIONS***

1. *In the Contract (as hereinafter defined) the following definitions words and expressions shall have the meaning hereby assigned to them except where the context otherwise required.*

- i) Institute shall mean the Indian Institute of Technology (IIT), Kanpur
- ii) The President shall mean the Board of Governor, IIT Kanpur.
- iii) The Engineers In-charge, who shall administer the work, shall mean the Executive Engineer (Electrical& AC) for electrical and Air-conditioning works.
- iv) Government or Govt. of India shall mean the Indian Institute of Technology represented by its Director.
- v) The term Director General of Works shall mean the Chairman, Building & Works Committee of the Institute.
- vi) Accepting authority shall mean the Director, IIT Kanpur or his authorized representative.
- vii) Superintending Engineer shall mean the Superintending Engineer of the Institute, who as overall In-charge and head of the Institute Works Department shall direct the contract.
- viii) Site Engineers shall mean the Sr.Assistant Engineer/Assistant Engineer & Jr. Engineer (AC/Electrical) for Electrical & Air-conditioning works, appointed by the Institute Works Department.

### 2. **Duties & Powers :**

#### i) Site Engineers:

The duties of the Site Engineer(s) are to watch and supervise the works and the workmanship employed in connection with the works, and to test and examine any materials to be used. He shall have no authority to relieve the contractor of any of his duties or obligations under the contract nor, except as expressly provided here under, to order any work involving delay or any extra payment by the Institute, nor to make any variation in the works.

The Engineer-in-charge, from time to time in writing, delegate to the Site Engineer (s) any of the powers and authorities vested in them. Any written instruction or written approval given by the Site Engineer (s) to the contractor within the terms of such delegation (but not otherwise) shall bind the contractor and the Institute as though it had been given by the Engineer-in-charge / Architect provided always as follows:

- a) Failure of the Site Engineer (s) to disapprove any work or materials shall not prejudice the power of the Engineer In-charge / Architect to subsequently

disapprove such work or materials and to order the pulling down, removal or breaking up thereof.

- b) If the contractor is dissatisfied by reason of any decision of the Site Engineer (s), he shall be entitled to refer the matter to the Engineer-in-charge / Architect, who shall thereupon confirm reverse or vary such decision.
3. The scope of contract comprises the construction, completion and maintenance of the works for (12) months after the completion and the provision of all labour, materials, construction of plant equipment and transpiration, temporary works and everything, whether of temporary or permanent nature required in and for such construction, completion and maintenance so far as the necessity for providing the same is specified in or reasonably be inferred from the contract. The contractors shall make his own arrangements for the store storage of materials, accommodation for his staff etc. and no claim for the temporary accommodation from the contractor shall be entertained.

The contractor shall carry out and complete the said work in every respect in accordance with this contract and as per the directions and to the satisfaction of the Engineer-in-charge/Architect. Issue of further drawings and /or written instructions, detailed directions and explanations which are hereinafter collectively referred to as instructions of the engineer-in-charge/ Architect's in regards to:-

- a. The variation or modification of the design, quality, or quantity of works or the addition or omission or substitution of any work.
- b. Any discrepancy in the drawings or between the schedule of quantities and /or drawings and/or specifications.
- c. The removal from the site of any materials brought thereon by the contractor and the substitution of any other material thereof.
- d. The dismissal from the works of any persons employed thereupon.
- e. The opening up for inspection of any work covered up.
- f. The amending /making good of any defects.

The contractor shall forthwith comply with and duly execute any instructions of work comprised in such engineers-in-charge instructions, provided always that the verbal instructions and explanations given to the contractor or his representative upon the works shall, if involving a variation , be confirmed in writing by the contractor within seven days and is not dissented in writing within a further seven days by the Engineer-In-Charge/Architect, such shall be deemed to be instructions of the Engineer-In-charge/Architect within the scope of the contract.

4. **Contract Document:**

- 4.1 The several documents, forming the contract, are to be taken as mutually explanatory of one another and in case of ambiguities or discrepancies the same shall be explained and adjusted by the Engineer-In-Charge who shall thereupon issue to the contractor its interpretation directing in what manner the work is to be carried out. In case the contractor feels aggrieved by the interpretation of the Institute then the matter shall be referred to the Superintending Engineer and his decision shall be final, conclusive and bind on both parties.

4.2 The drawings etc. shall remain in the custody of the Institute. Two complete sets of drawings, specification and bill of quantities shall be furnished by the Engineer-In-Charge to the contractor in such time which must not delay the progress of the construction and the Institute shall furnish copies of any additional drawings, which in their opinion may be necessary for the execution of any part of the work. One complete set shall be kept on the work site and the Engineer-In-Charge and his representatives shall be, at all reasonable times, have access to the same. The contractor shall study the drawings thoroughly before the commencement of work. In case of any discrepancy, the contractor shall seek clarification before proceeding with the works. Figured dimensions are in all case to be accepted in preference to the scaled sizes. Large scale details shall take preference over small scale one.

The contractor shall give adequate notice in writing to the Engineer-in-charge of any further drawings or specification that may be required for the execution of the works or otherwise under the contract.

The Engineer-in-charge shall have full powers and authority to supply the contractor from time to time during the progress of the work such drawings and instructions as shall be necessary for proper execution and the contractor shall carry out and be bound by the same.

4.3 The successful tenderer shall be required to enter into an agreement with the Institute. The Bill of Quantities & rates filled by the successful tenderer in, the General Condition of the Contract for CPWD works 2014, CPWD specifications for Civil, Electrical & Air-conditioning works, the special conditions, additional specifications, negotiation letter and the award letter etc. shall form part of the agreement to be signed by the successful tenderer. The cost of stamp paper and stamp duty, required for the agreement, shall be borne by the contractor.

## 5. **Contract Agreement:**

The contractor shall, when called upon to do so, enter into and execute a contract agreement in the form annexed as annexure `A` with such modifications as may be necessary. The contract agreement, inclusive of its enclosures, shall remain in the custody of the Superintending Engineer, Institute Works Department, IIT Kanpur and the made available him as and when required contractor shall however be supplied, an attested copy there free of cost.

6. All tenders are required to deposit earnest money in the form of FDR/CDR in the only duly endorsed in favour of **Director, IIT Kanpur. Earnest money should be enclosed in a separate sealed envelope and tender documents should be enclosed in a another envelope superscribed "Earnest Money- Name of work "Item Rate-Tender-Name of Work"** on the top of envelope. At the time of opening of tender earnest money envelope will be opened first and in case earnest money is not found in the requisite from or amount envelope containing item rate tender of the party concerned shall be opened and will be summarily rejected and documents submitted will be confiscated by the Institute.

8. Canvassing in connection with tenders is prohibited and the tenders, submitted by the tenderers who resort to canvassing, are liable for rejection.

9. Tenderers shall have to sign the attached declaration (Appendix B) and if the declaration is not found to represent a true statement of facts the contract is liable to be cancelled, earnest money forfeited and the contractor shall have no claim on the Institute.

10. Tenderers are not allowed to make additions and alterations in the tender document. Any additions and alterations, if incorporated in the tender, shall be at the tenderer's risk since the modified tender is liable for rejection.

Conditional tenders violative of the spirit and the scope or the terms & conditions of the tender, are liable to be rejected without assigning any reasons. Tenders with any form of rebate shall be rejected summarily.

11. Water and electricity required for electrical & air-conditioning works shall be supplied free of charge.

12. Stamp duty on the security money shall also be borne by contractor as per prevailing notification of U.P Govt.

13. Income tax shall be deducted as per prevalent law.

14. Conditions for Electrical and Air-conditioning Works:-

14.1 All chase cuttings in the wall, for recessed conduits & boxes and drilling the holes shall be done with power operated machines only. No chase shall be allowed to be cut manually with the use of hammer & chisel.

14.2 All cuttings in cement plaster and brick shall be made good by using cement mortar 1:3 (1 part cement, 3 part coarse sand)

14.3 The cut surfaces shall be repaired by an experienced mason only so as to match the repaired plaster with the original.

14.4 All such repaired surfaces shall be cured for 3 to 4 days to keep the surfaces wet, using water spray machine (hand/motor operated) and avoid unnecessary flooding of the area.

15. Payment shall be regulated as under

a.) 75% of the tendered rate on receipt of materials at site.

b.) 15% of the tendered rate on installation and connection.

c.) 10% of the tendered rate on testing and commissioning.

16. Drawings/Data required prior to commencement of electrical/air-conditioning works:-

a. Shop floor drawings of refrigerant piping and equipments.

17.1 The following drawings shall be provided by the Engineer-In-Charge of the work:-

1. Outdoor Units & indoor units layout drawing..

2. Cable routing drawings showing details of size, type and no. of cables and mode of installation.

3. Ducting /refrigerant pipe/drain pipe/unit positioning etc., drawing showing details of size, type, and mode of installation of indoor and outdoor equipments.



- 17.2 Following drawings shall be furnished by the contractor for the approval of the Engineer-In-charge.
- a. G.A and schematic drawings of Outdoor/Indoor unit,refrigerant piping layout.
  - b. Ducting /refrigerant pipe /drain pipe etc., drawing showing details of size, type, and mode of installation.
18. Completion drawings:  
On completion of works and before issuance of completion certificate, the contractor submit completion drawings in the form of four complete set of originals (reproducible)
- i) As built GA and schematic drawings of Indoor & outdoor ac units installations.
  - ii) Technical literature, test certificates, and operation and maintenance manuals for indoor/outdoor VRF ac units, compressors,& controllers required.
19. Works Inspection and Testing of Equipment:
- a.)Prior to dispatch of equipment the Institute reserves the right to inspect the same at the manufacturer's works and the contractor shall provide and secure every reasonable access and facility at the manufacturers works for inspection, for witness of all acceptance and routine tests as per relevant Indian Standards. Contractor shall give a reasonable notice of about 15 days for the purpose of test, and witness of all major equipments.
  - b.)Pre-commissioning test: All routine tests shall be carried out on the electrical & air-conditioning equipment. Protective & measuring devices should be checked for calibration of window/split/tower ac units should be checked for air quantities and temperature. All grills/diffusers should be checked for balanced air quantities.
20. **Rates:** The work shall be treated as on works contract basis and the rates tendered shall be for complete item of work and all charges for items contingent to the work, such as packing, forwarding, insurance, freight and delivery at site for the materials to be supplied by the contactor, watch and ward of all materials at the site, labour related expenses as per relevant labour laws, testing of materials/ samples etc. excluding Goods & Service tax (GST).
21. **Taxes & Duties:**
- 21.1 Being an indivisible works contract, no other tax is payable other than GST. The GST shall be as applicable to IIT Kanpur as per Government rules.
22. The earnest money of the unsuccessful tenderers shall be refunded on written request, within 1(one) month of the award of work. The earnest money of the successful tenderer shall however be adjusted towards the security deposit.
23. The tender document & drawings in respect of the work can be seen in the o/o Executive Engineer

24. The tender document contains \_\_\_\_\_ pages. No page of the tender document shall be removed, mutilated, detached, or cancelled.
25. Rates for finished works shall be given for each items separately, both in words & figures. In the event of non compliance the tender shall be deemed incomplete and liable for rejection.
25. All entries by the tenderer should be made in one ink and one hand writing only. Tenders should be filled in legible hand writing and should not contain erasures, corrections and overwriting as far as possible. However if it becomes necessary, each correction etc. should be properly attested under dated signature.
26. The work shall be executed on the basis of the following CPWD specifications:
- i) Electrical & HVAC Works :
- General specifications for Electrical Works Part-1 (Internal) 2013 with up to date corrections.
  - General specifications for electrical works (external) 2013 with upto date corrections.
  - General specifications for electrical works Part-VII (DG set) 2013 with upto date corrections.
  - General specifications for electrical works Part-IV Sub-station- 2013 with upto date corrections.
  - General specifications of HVAC works 2017 with upto date corrections.
28. For the purpose of clause 12 of the General conditions of contract the following schedule of rates shall be applicable.
- i) Electrical Works: Electrical Works , air-conditioning & refrigeration works  
:Based upon prevailing market rates
29. The special conditions listed above shall take precedence over all above provisions of the contract. The General Condition of contract for CPWD works shall be generally followed including the clause 21 i.e. work shall not be sublet.
30. The contractor shall have to execute the work in such place and condition where other agencies will also be engaged for other works such as site grading, filling and leveling, interiors, landscape, and electrical and mechanical engineering works, etc. No claim shall be entertained due to work being executed in the above circumstances.
31. No contractor, to whom the provisions of the BOCW Act apply, shall be allowed to commence work on the campus unless he has produced the 'Registration Certificate' issued by the office of Dy. CLC (Central)
32. The contractor shall engage only such workers who are registered as beneficiaries with U.P. BOCW Welfare Board and in case of engagement of new workers; he shall ensure the submission of applications for registration of such workmen within appropriate time.

33. A certificate for administrative convenience shall be obtained from the contractor covered under BOCW Act whether he has engaged 10 or more workmen while working in the Institute and only thereafter, Cess @1% from the bills raised by him shall be deducted at source for all running works. Cess, so deducted shall be deposited with the BOCW Welfare Board.
34. As per clause 36 (I) of GCC : It should be noted that license wire man shall only be allowed for the wiring work.

**Section 1:                    ADDITIONAL SPECIFICATION FOR AIR-CONDITIONING &  
REFRIGERATION WORKS**

**TECHNICAL SPECIFICATIONS**

**Basis of Design**

**1.1      AIRCONDITIONING SYSTEM**

*The various parameters influencing the air conditioning system design have been furnished below.*

**a.      Orientation**

*The building orientation is as envisaged in the architectural plans.*

**b.      Outside design conditions**

*The outside design conditions for **Kanpur** have been given here under:*

<b>Seasons</b>	<b>Dry Bulb Temperature</b>	<b>Wet Bulb Temperature</b>
Summer	109 F (42.8C) db	79F (26.1 C) wb
Monsoon	94 F (34.4 C) db	83 F (28.3 C) wb
Winter	48 F (8.9 C) db	43 F (6.1 C) wb

**c.      Cleanliness Standards:**

*The cleanliness standard as defined by the Federal Standard /FDA guidelines shall apply for clean rooms (if any).*

**FEDERAL STANDARD 209B**

	Clean Room Class		
	100	10,000	100,000
Max. count of particles 0.5um or larger/of (count/liter)	100 (3.5)	10,000(350)	100,000 (3500)
Max. count of particles 5um or larger/of (count/liter)	--	65 (2.3)	700(25)
Pressure inWG (mmWG)	0.05 (1.27), min	0.05 (1.27), min.	0.05 (1.27), min

*Guideline by clean room type :*

Vertical laminar flow	Conformed in whole working area	Ordinarily conformed in whole area	Conformed in whole area
Horizontal laminar flow type	Ordinarily conformed in first working position	Ordinarily conformed in whole working area with proper manning and work siting	Ordinarily conformed in whole area
Conventional type	Not conformed in working condition	Sometimes conformed when clean bench is used .	Can be conformed under severe control

**2. INSIDE DESIGN CONDITION & DESIGN PARAMETERS TO BE CONSIDERED ARE AS UNDER:**

**(Class 10000) AHU 1, INNER CLEAN LAB**

AREA Considered	4572mm X 2970mm
Class of Cleanliness	ISO 7 ( Class 10000)
Temperature	23 deg C +/- 2 deg C
Relative Humidity	50 % +/- 5 %
Area of the clean room	<b>13.57 SQ M</b>
False ceiling height From FFL	2.4M
Equipment load for Heat Load Calculations	2 kW
Number of people	4
Min Number of Fresh air changes	≥ 3 ACPH
Minimum ACPH to Achieve ISO 7 (Class 10000)	50
Minimum HEPA Coverage	10 %
Terminal Air Velocity at outlet of HEPA surface inside cleanroom	≥ 85 FPM +/- 10 fpm
H-14 HEPA filters size around 1200 x 600 x152mm depth with efficiency of 99.995% down to 0.3 micron level The filter media of glass fiber & min depth shall be 50 mm.	Approximate Air flow rate around <b>600 cfm</b> per HEPA filter. Material of casing shall be Aluminum.
Positive Pressure inside Cleanroom	+ 25 Pa +/- 5Pa (ref to Atmosphere). But Minimum +15 Pa with reference to adjacent rooms is important parameter.
Lighting	Flat diffuser type/surface mounting WHITE light 550 – 600 LUX & color Temperature 4000 K
Total Process exhaust	98 cfm

**(Class 100000) AHU 2, ACID FUME LAB**

AREA Considered	8885mm X 4580mm
Class of Cleanliness	ISO 8 ( Class 100000)
Temperature	23 deg C +/- 2 deg C
Relative Humidity	50 % +/- 5 %
Area of the clean room	<b>40.67 SQ M</b>
False ceiling height From FFL	2.4 M
Equipment load for Heat Load Calculations	<b>2 kW</b>
Number of people	8
Exhaust air through fume hoods	2500-3000CFM
Air re-circulation	1500 CFM
Minimum ACPH to Achieve ISO 8 (Class 100000)	30
Minimum HEPA Coverage	8 %
Terminal Air Velocity at the Surface of the HEPA Filter inside cleanroom	≥ 85 FPM +/- 10 fpm
H-14 HEPA filters size around 1200 x 600 x152mm depth with efficiency of 99.995% down to 0.3 micron level The filter media of glass fiber & min depth shall be 50 mm.	Approximate Air flow rate around <b>600 cfm</b> per HEPA filter. Material of casing shall be Aluminum.
Positive Pressure inside Cleanroom	+ 10 Pa +/- 5Pa (ref to Atmosphere). But Minimum +15 Pa with reference to adjacent rooms is important parameter.

***AHU 3, OFFICE, INSTRUMENT ROOM ETC.***

<b>AREA Considered</b>	14740mm X 7213mm
<b>Temperature</b>	23 deg C +/- 2 deg C
<b>Relative Humidity</b>	50 % +/- 5 %
<b>Area of the room</b>	<b>106.31 SQ M</b>
<b>False ceiling height From FFL</b>	2.4 M
<b>Equipment load for Heat Load Calculations</b>	<b>15 kW</b>
<b>Number of people</b>	10

## **Technical requirements & Specifications of clean rooms & related HVAC system**

### **3.1 REQUIREMENTS & ARRANGEMENTS IN GENERAL FOR DESIGN, SUPPLY, CONSTRUCTION, COMMISSIONING, TESTING & VALIDATION OF THE PROPOSED CLEAN ROOM for Ground floor C block Pre-Fab building near old SAC building:**

#### **3.2 CLEAN ROOM COMPONENTS:**

The cleanliness level to be achieved & maintained in the proposed areas is indicated in the ROOM BOOK and the same is to be achieved by providing necessary cleanroom compatible wall panels, ceiling grid, ceiling panels, covings, flooring, HEPA filters with modules, light fixtures, HVAC, etc Complete as applicable.

#### **3.3.0 THE CLEAN AIR RECIRCULATION MANAGEMENT:**

shall comprise of suitable capacity AHUs comprising of cooling coils, stages of filters, fan & electrical motors etc. Supply Air ducts, branch ducts, Return Air ducts, fabricated Return Air raisers located inside the Clean rooms at required location of the Cleanroom Walls, Volume control Dampers, RA grilles etc, Complete.

**Supply & return air Management of Clean air:** Supply/return air shall be from AHU via supply air ducts, branch ducts, and flexible ducts and through terminally fitted hooded HEPA filters fixed in the false ceiling. The clean air is delivered to the clean spaces through these terminally fitted HEPA filters.

The return air from Cleanrooms to the return path can be via return air grilles & return air risers with Volume Control Dampers (VCD), fixed on the periphery of clean room wall panels fixed at "low" level of the Cleanroom wall return system. The RA grill system consisting of linear type grilles made out of Aluminum material along with VCD and having GI powder coated collars, located at low level of wall panels, fixed on the periphery of the cleanroom. The fabricated return air raisers made out of minimum 22 G thick GI material duly insulated along with suitable supports & accessories. They shall be connected to the main return air ducts and this main return air duct will rise up & connected to the mixing chamber to the AHU.

#### **3.4 AIR VELOCITY TO BE CONSIDERED FOR CLEAN AIR:**

Supply air velocity of the main duct of AIR HANDLERS shall not exceed 1200 fpm & accordingly the ducts shall be sized. The return air velocity considered to design the size of Return Air raisers shall not exceed 500 fpm & velocity for Return Air grilles shall not exceed 350 fpm. (These velocity values are of an indicative nature; the vendor should verify these depending upon the design conditions.)

#### **3.6 HEPA FILTERS FOR ALL CLEANROOM LABS:**

**HEPA Filters** shall be of Hooded HEPA filter module with H-14 HEPA Filters. The HEPA filter module shall be standard model of around 2 feet width x 4 feet length ( about 610mm X 1270 mm) delivering not less than 650 CFM-700 CFM. The height of filter media pack shall not be less than 2". The casing of filter module shall be of Aluminum. HEPA filter provided in the module shall be 99.995% down to 0.3 microns H - 14 in accordance with IES practice or equivalent standard.

The HEPA filter media shall be glass fiber, the frame/casing of HEPA filter shall be aluminum. The filter face guard shall be epoxy coated expanded steel. The HEPA filter shall be factory sealed for leak proof operation and shall be easy to be replaced at site. The filter module shall be provided with volume control damper, DOP port and necessary supports.

#### **4.0 TECHNICAL SPECIFICATION FOR CLEAN ROOM INTERIOR WORKS.**

WALL PANELS shall be GPSP steel (Galvanized Plain Single Pass) /PCGI/GIPC Double Skin Wall panels of total thickness not less than 80 MM, sandwiched with self-extinguishing quality PUF of density not less than  $40 \pm 2$  kg/cum as core Material. With both inner & outer Skins with duly powder coated steel sheets not less than 0.8mm thick. The skins shall be hot dip galvanized with zinc coating not less than 180gm/sq.m on both sides. The panel shall be smooth finished and both side of the panel shall be off white/required color, the coating thickness shall not be less than 60 microns including the primer



The panels shall be manufactured to a minimum width of **not less than 1100 mm and of any suitable length as required in a continuous length lamination.**

The Wall panels systems offered shall be with suitable joining profiles & fittings shall be used in order to facilitate removal & replacement of panels in the event of moving the process tools & equipment in and out of cleanroom as and when required.

**IMPORTANT NOTE: Tongue & groove type of joining the wall panels are not acceptable. Also pre coated/pre painted / high pressure laminate/one side GPSP & another side HPL wall panels are not acceptable.**

**Both sides of the wall panels shall be finished with GPSP/PPGI/PCGI/GIPC double skin steel sheets of minimum 0.8 mm thick as mentioned above.**

**4.1 Vertical Pillars inside the Cleanrooms shall be Cladded using GPSP (Galvanized Plain Single Pass) steel /PCGI/GIPC Double Skin Wall panels & total thickness not less than 50 MM, sandwiched with self-extinguishing quality PUF of density not less than 38kg/cum as core Material. With both inner & outer Skins with duly powder coated steel sheets of not less than 0.8mm thick. The skins shall be hot dip galvanized with zinc coating not less than 180gm/sq.m on both sides. The panel shall be smooth finished and both side of the panel shall be half white color, the coating thickness shall not be less than 60 microns including the primer.**

**IMPORTANT NOTE: Tongue & groove type of joining the cladding panels are not acceptable. Also pre coated/ pre painted / high pressure laminate/one side GPSP & another side HPL wall panels are not acceptable. Both sides of the wall panels shall be finished with GPSP/PCGI/GIPC double skin steel sheets of minimum 0.8 mm thick.**

**4.3 GLAZED VIEW PANELS:** Clean room walls shall have double glazed view windows of size not less than **900 mm width X 900 mm height** & shall have toughened glass panels of thickness not less than 5mm and all the joints between toughened glass and wall panels shall be sealed.

**4.4 COVINGS:** Suitable coving of minimum radius 50 mm made out of polyvinyl chloride (PVC) shall be fixed along the joints between wall & the floor, wall & the false ceiling joints between the wall panels, 3D corner & 2D corner covings at the corners as required.

#### **4.5 FALSE CEILING GRID SYSTEM WITH CEILING BLANK PANELS FOR THE CLEANROOMS LABS:**

The false ceiling system for the cleanroom area shall be provided with ceiling grid system consisting of inverted T-grid of extruded aluminum anodized surface, wall angle, suspender rod, turnbuckle, nuts, bolts, anchor fasteners etc., as required for fixing the panels, Light fixtures, hooded HEPA filter module etc., and cost for the ceiling grid system deemed to be included in the quoted rate for false ceiling. The width of main "T" bar shall not be less than 55mm extruded aluminum anodized surface.

Ceiling grid configuration may be around 1200mm length and 600 mm width and shall be suitable for fixing module etc., all the suspended material shall be galvanized finish. The ceiling grid shall be suitable for accommodating individual module with HEPA filter; light fixture, blank panels etc., and shall be provided with virgin neoprene or PVC gasket.

The False ceiling panel shall be GPSP (Galvanized Plain Single Pass) steel /PCGI/GIPC Double Skin steel ceiling panels & total thickness not less than 50 MM, sandwiched with self-extinguishing quality PUF as core Material of density not less than 40±2kg/cum. With both inner & outer Skins with duly powder coated steel sheets of not less than 0.8mm thick. The panel shall be smooth finished and both side of the panel shall be off white color, the coating thickness shall not be less than 60 microns including the primer.

Necessary services/trap doors shall be provided to the false ceiling for maintenance on the top of the false ceiling.

All the joints and corners between ceiling and wall panels, wall panels and wall panels, wall panel to floor of modular clean room shall be provided with PVC R 50 coving with same panel finish and color.

**5.1 Lighting System:** Flat diffuser type/surface mounting type white fixtures shall be provided for 500 - 600 lux at working table level & color temperature of 4000 K in other areas (diffusion lab, air lock,

changing room, service corridors and locker rooms). Provision shall be made for a few light fixtures to provide emergency illumination in the event of mains power failure.

**6.0 CUTOUT IN WALL PANEL AND CEILING PANEL:** Suitable factory made cutouts wherever required shall be provided in the wall panel/ceiling panel as applicable for fan filter units, hooded HEPA filters, light fixture, return air grills, power sockets, communication outlets, LAN outlets, cables, pipes, exhaust ducts, Magnehelic gauge, smoke sensors, pendants, utilities etc., are also to be included in the quotation after conducting an inspection to the proposed clean room and utility

**6.1 CLEAN ROOM DOORS:** Single leaf doors /Double leaf doors, flush doors, roller hinged type. The leaf shall be fabricated out of similar material to wall panels as mentioned above in the wall panel requirements. The size of the single door/double doors/Emergency doors shall be as mentioned in the Drawing. Clear size measured shall be inner to inner of frames.

The view window of suitable standard size, having min 5mm thick double glass duly fixed and sealed to the door panels. The door shall be provided with door closer, lock & other standard accessories. The door handles, push plate and hinges shall be of stainless steel.

The thickness of door shall not be less than 44 mm, made out of GPSP steel /PPGI/ GI Powder Coated steel double skin door not less than 44mm leaf thickness made of 0.80 mm GI sheet for door leaf with PUF infill and door frame made out of 1.20mm thick GI profile.

**7.0 a) FLOORING:** The clean rooms floor shall be of Electro Static Conductive type, vinyl tiles, not less than 3mm thick and not less than 610 mm x 610 mm size.

Electrostatic (EC) type flexible homogenous, compressed ESD vinyl floor tiles in flooring/skirting, having minimum size 610 mm x 610 mm x 3mm thick. The ESD tiles shall have electrical conductive resistance in the range of  $2.5 \times 10^4$  Ohm to  $1 \times 10^7$  ohm and shall have dimensional stability of 0.05%, minimum decay time of 0.25 sec. as per ASTM /DIN/EN standards and shall be resistant to acids, chemicals and fire. ESD floor tiles shall be laid on existing cement concrete (VDF) flooring including providing and laying of approved conductive primer with necessary conductive adhesive. Joint between the tiles shall be PVC welded and copper foils shall be provided and laid. The copper net shall be grounded. The copper strip shall be laid by cutting a groove connected to a separate earth point exclusively made for this purpose.

**8.0 a) STRUCTURAL WORK** for hooking the false ceiling system, Light Fixtures & Hooded HEPA Modules: Shall provide Additional structural work for hooking false ceiling, HEPA modules, and light fixtures etc using Suspension structural steel made of suitable channels & I sections using heavy duty unistruts & Complete

**8.0 b) ELECTRICAL CONTROL SWITCHES & SOCKETS for Cleanroom Accessories:** Shall provide Electricals with switchboards for instruments, Lighting, Garment Cubicles & other Cleanroom accessories.

#### **9.1.0 MAGNEHELIC GAUGE**

The Magnehelic gauge shall be clean room compatible type of size 100mm diameter with pressure range of 0-10 mm .the Magnehelic gauge shall be supplied with necessary SS mounting/box, PVC tubing etc.,

**9.3** Any other item required shall be provided (which is not mentioned in this documents) to complete the Cleanroom to achieve the specified Cleanroom in total as per ISO standard.

**9.3 RA RISERS** (Powder Coated Galvanized Iron): Shall include Modular Wall panels **cladding for RA RISERS** with pure polyester powder coating of minimum 80 Microns. Sandwich Panels made up of Galvanized Iron sheet Galvano Plain Single Pass (GPSP) GI with Zinc Coated minimum 80 GSM,Grade-D, Minimal Spangle, The skins shall be galvanized with zinc coating not less than 180gm/sq.m on both sides. Wall Cladding Panels shall be with Infill of PUF insulation having Density of minimum  $38 \pm 2$  Kg/M<sup>3</sup>, including all hardware accessories, Bottom track & top track etc to support and joint sealing with Food Grade silicon sealant. Sheet thickness - 0.8 mm on both sides & total PILLAR Cladding Panel Thickness shall be not less than - 50 mm, with smooth surface finish. Complete

**9.4.0 Validation & Commissioning of Clean room: The Contractor should validate the Clean room as per ISO14644 & shall include validation of parameters like:**

**DQ, IQ and OQ, Documents to be submitted along with Validation Reports, Test Certificate for equipment/Materials & Detailed engineering drawing**

- **Temperature Mapping**
- **Relative Humidity Mapping**
- **Particle count**
- **Filter Integrity test**
- **Air velocity test**
- **Differential room pressure test (pressure Zoning)**
- **Recovery test**
- **Air Flow pattern with videography**
- **Air balancing.**
- **Pressure balancing**

## **DOUBLE SKIN AIR HANDLING UNITS**

### **Scope**

The scope of this section comprises of supply, erection, testing and commissioning of AHRI certified double skin construction air handling units with thermal break profile, conforming to these specifications and in accordance with requirements of drawings and schedule of quantities.

### **Type**

The air handling units shall be double skin construction, draw-thru type comprising of various sections such as pre filter, fine filter section, coil section, fan section, mixing chamber, SA, RA, FA dampers factory assembled as elaborated in drawings and schedule of quantities.

### **Capacity**

The air handling capacities, maximum motor HP, static pressure shall be as shown on drawings, appendices and schedule of quantities.

### **Housing/Casing**

The housing/casing of the air-handling unit shall be of double skin construction. The housing shall be so constructed that it can be delivered at site in total/semi knock down conditions depending upon the locations. The casing strength of the assembled Air Handling Unit shall be designed to meet BS EN 1886, Class 2A and the casing air leakage of the assembled Air Handling Unit shall be designed to meet BS EN 1886, Class B.

The framework shall be extruded aluminium hollow sections filled with preformed insulation section. Frames shall be assembled using mechanical joints to make a sturdy and strong framework for various sections.

Double skin panels (each not exceeding 750mm wide) shall be made out of 22/24 gauge pre painted galvanized steel sheet on outside and 24 gauge plain galvanized sheet inside with min 46 mm thick injected CFC free PU foam insulation in between. These panels shall be bolted from inside on to the frame work with soft rubber gasket in between to make the joints air tight.

Frame work for each section shall be bolted together with soft rubber gasket in between to make the joints air tight. Suitable doors with pressure die cast aluminium hinges and latches shall be provided for access to various panels for maintenance. The entire housing shall be mounted on steel channel frame work. Each component section of the Air Handling Unit shall have matching cross- sectional dimensions of the same construction showing a neat exterior along the length of the unit and a clean interior appearance to ensure even air flow through each plant item.

Drain pan shall be constructed out of 18 gauge stainless steel with necessary slope to facilitate rapid removal of condensate water. Drain pan shall be factory insulated with minimum 9mm thick closed cell elastomeric insulation as required. Necessary supports will be provided to slide the coil in the drain pan. Outlet shall be provided from the drain pan in a manner that access panel can be opened without disconnecting the drain pipe connection.

### **Motor and Drive**

Fan motors shall be high efficiency IE-03 suitable for operation on 415 + 10% volts, 50 cycles, 3 phase, squirrel cage, totally enclosed fan cooled with IP-55 protection and class F insulation and class B temperature rise. Motors shall be especially designed for quiet operation and motor speed shall not exceed 1440 RPM & 2800 RPM for fans below 3500 Cfm. Drive to fan shall be provided through belt-drive arrangement. Belts shall be of the oil-resistant type. Efficiency of motors shall be 85 % or more. As an option belt guards shall be provided with a painted metal sheet belt guard that totally encloses the drive, the guard shall be rigidly attached to the fan base support structure. The motor shall be suitable for VFD controlling.

### **Fan**

The fan shall be forward curved floor standing double inlet double width type. The wheel and housing shall be fabricated in galvanized steel construction as per manufacturer standard. The fan impeller shall be mounted on a solid shaft supported to housing with angle iron frame/spider and self lubricated sealed eccentric type ball bearings. The impeller and fan shaft shall be statically and dynamically balanced. The fan outlet velocity shall not be more than 1800 FPM. Fan housing with motor shall be mounted on a common steel base mounted inside the air handling housing on anti-vibration spring mounts or rubber mounts. The fan outlet shall be connected to casing with the help of fire retardant canvass.

### **Cooling /Heating Coils**

Chilled/Hot water coils shall have 12.5 mm to 16 mm dia tubes of wall thickness not less than 24 G with aluminium fins firmly bonded to copper tubes assembled in zinc coated steel frame. Face and surface areas shall be such as to ensure rated capacity from each unit and such that air velocity across each coil shall not exceed 500 FPM. The coil shall be pitched in the unit casing for proper drainage. Each coil shall be factory tested at 21Kg/Sqcm air pressure under water. Tubes shall be hydraulically/ mechanically expanded for minimum thermal contact resistance with fins. Fin spacing shall be 11 to 13 fins per inch (4 to 5 fins per cm.)

### **Filters**

Each unit shall be provided with a factory assembled filter section containing cleanable type pre-filters 10 micron 90% efficiency and fine filter with 3 micron 99% efficiency of synthetic media having anodized aluminium channels. The media shall be supported with HDP/AL mesh. Filter face velocity shall not exceed 500 FPM. Filters shall fit so as to prevent by-pass. Holding frames shall be provided for installing a number of filter cells in banks. These cells shall be held within the frames by sliding the cells between guiding channels.

### **Heater Section**

Each Air Handling units shall be provided with heater section for monsoon reheat & winter heating as required. The section shall include all control such as heating thermostat, control wiring etc. The unit shall also incorporate necessary safety features as mentioned under strip heaters. The heater terminals shall be extended in order to

check parameters without opening the AHU door/panels. The capacity of the heater strip to be provided by the manufacturer at the time of drawing approval by Engineer In Charge.

Supply and install (or paint) on the exterior of the unit in a prominent position adjacent to the heater bank a notice, which shall read.

### **Fire**

This unit contains electric heating elements and is fire resistant. In the event of fire, disconnect the power by the main isolating switch.

(Characters to be in white, 15mm high for the word "FIRE" and 5mm high for the rest on a red background)

### **Accessories**

Each air handling unit shall be provided with manual air vent at highest point in the cooling/heating coil and drain plug at the bottom of the coil. Besides, the following accessories may be required at air handling units, the detailed specifications are given in individual sections, and quantities separately described in the schedule of quantities.

Motorized self balancing pressure independent valves located in chilled / hot water lines connecting to the coil. This valve shall be operated by the cooling/ heating thermostat and shall control the flow of chilled/hot water.

Insulated butterfly valves/balancing valves, Y-strainer, unions and condensate drain piping upto sump or floor drain in air handling unit rooms as described in section "Piping".

Dial type thermometer in the thermometer wells and pressure gauge (with cocks) within gauge ports in chilled/ hot water supply and return lines as per the section "Automatic Controls and Instruments".

### **Performance Data**

Air handling units shall be selected for the lowest operating noise level. Technical submittal of air handling units shall be prepared for Consultants approval prior to procurement as mentioned under clause 7 under Special Conditions. Fan performance rating and power consumption characteristics shall be submitted and verified at the time of testing and commissioning of the entire installation.

### **Testing**

Cooling/heating capacity of various air handling unit models shall be computed from the measurements of air flow and dry and wet bulb temperatures of air entering and leaving the coil. Air flow measurements shall be carried out using air capture hood and temperature measurements by accurately calibrated thermometers by the vendor. Computed results shall conform to the specified capacities and quoted ratings. Power consumption shall be computed from measurements of incoming voltage and input current.

**Section 2: DUCT WORK AND OUTLETS**

**1. General**

- 1.1 The work under this part shall consist of furnishing labour materials, equipment and appliances as specified necessary and required to install all sheet metal and other allied work to make the air conditioning supply, ventilating, and exhaust system ready for operation as per drawings.
- 1.2 Except as otherwise specified all duct work and related items shall be in accordance with these specifications.
- 1.3 Duct work shall mean all ducts, casings, dampers, access doors, joints, stiffeners and hangers.

**2. Duct Materials**

- 2.1 The ducts shall be fabricated from galvanized steel sheets class VIII conforming to ISS:277-1962 (revised) or aluminium sheets conforming to ISS:737-1955 (wherever aluminium ducts are specified).
- 2.2 All duct work, sheet metal thickness and fabrication unless otherwise directed, shall strictly meet requirements, as described in IS:655-1963 with amendment-I (1971 edition)

The thickness of the sheet shall be as follows :-

	Size of Duct	Sheet Thickness	Type of Joints	Bracing if any
2.2.1	Upto 750 mm	0.63 mm 24 Ga	G.I. Flange	
2.2.2	751 mm to 1000 mm	0.80 mm 22 Ga	25x25x3 mm Angle iron frame with 8 mm dia nuts & bolts	25x25x3 mm at the rate of 1.2 M from joints
2.2.3	1001 mm to 1500 mm	0.80 mm 22 Ga	40x40x5 mm Angle iron frame with 8 mm dia nuts & bolts	40x40x5 mm at the rate of 1.2 M from joints
2.2.4	1501 mm to 2250 mm	1.00 mm 20 Ga.	50x50x5 mm Angle iron frame with 10 mm dia nuts & bolts at 125 mm centre.	40x40x3 mm at the rate of 1.2 M to be Braced Diagonally
2.2.5	2251 mm and above	1.25 mm 18 Ga.	50x50x6 mm Angle iron frame with 10 mm dia nuts & bolts at 125 mm centre.	40x40x3 mm at the rate of 1.6 M from joints
2.3	The gauges, joints and bracings for sheet metal duct work shall further conform to the provisions as shown on the drawings.			

- 2.4 Ducts larger than 600 MM shall be cross broken, duct sections upto 1200 MM length may be used with bracing angles omitted.
- 2.5 Changes in section of duct work shall be affected by tapering the ducts with as long a taper as possible. All branches shall be taken off at not more than 45 DEG. Angle from the axis of the main duct unless otherwise approved by the Engineer-In-Charge.
- 2.6 All ducts shall be supported from the ceiling/slab by means of M.S. Rods of 9 MM (3/8")DIA with M.S. Angle at the bottom. The rods shall be anchored to R.C. Slab using metallic expansion fasteners.

### 3. **Installations**

- 3.1 During the construction, the contractor shall temporarily close duct openings with sheet metal covers to prevent debris entering ducts and to maintain opening straight and square, as per direction of Engineer-In-Charge.
- 3.2 Great care should be taken to ensure that the duct work does not extend outside and beyond height limits as noted on the drawings.
- 3.3 All duct work shall be of high quality approved galvanized sheet steel guaranteed not to crack or peel on bending or fabrication of ducts. All joints shall be air tight and shall be made in the direction of air flow.

The ducts shall be re-in forced with structured members where necessary, and must be secured in place so as to avoid vibration of the duct on its support.

- 3.4 All air turns of 45 degrees or more shall include curved metal blades or vanes arranged so as to permit the air to make the abrupt turns without an appreciable turbulence. Turning vanes shall be securely fastened to prevent noise or vibration.
- 3.5 The duct work shall be varied in shape and position to fit actual conditions at building site. All changes shall be subjected to the approval of the Engineer-In-Charge. The contractor shall verify all measurements at site and shall notify the Engineer-In-Charge of any difficulty in carrying out his work before fabrication.
- 3.6 Sponge rubber or approved equal gaskets of 6 MM maximum thickness shall be self adhesive installed between duct flanges as well as between all connections of sheet metal ducts to walls, floor columns, heater casings and filter casings. Sheet metal connections shall be made to walls and floors by means of wooden member anchored to the building structure with anchor bolts and with the sheet screwed to them.
- 3.7 Flanges bracings and supports are to be black, mild steel and are to be painted with rust proof primer on all surfaces before erection. Accessories such as damper blades and access panels are to be of materials of appropriate thickness and the finish similar to the adjacent ducting, as specified.
- 3.8 Joints, seams, sleeves, splitters, branches, takeoffs and supports are to be as per duct details as specified, or as decided by Engineer-In-Charge.
- 3.9 Joints requiring bolting or rivetting may be fixed by Hexagon nuts and bolts, stove bolts or buck bolts, rivets or closed centre top rivets or spot welding. Self tapping screws must not be used. All jointing material must have a finish such as cadmium plating or Galvanized as appropriate.



- 3.10 Fire retarding flexible joints are to be fitted to the suction and delivery of all fans. The material is to be normally double heavy canvass or as directed by Engineer-In-Charge. On all circular spigots the flexible materials are to be screwed or clip band with adjustable screws or toggle fitting. For rectangular ducts the material is to be flanged and bolted with a backing flat or bolted to mating flange with backing flat.
- 3.11 The flexible joints are to be not less than 75 MM and not more than 250 MM between faces.
- 3.12 The duct work should be carried out in a manner and at such time as not to hinder or delay the work of the other agencies especially the boxing or false ceiling contractors.
- 3.13 Duct passing through brick or masonry, wooden frame work shall be provided within the opening. Crossing duct shall have heavy flanges, collars on each side of wooden frame to make the duct leak proof.

#### 4. **Dampers**

- 4.1 At the junction of each branch duct with main duct and split of main duct, volume dampers must be provided. Dampers shall be two gauges heavier than the gauge of the large duct and shall be rigid in construction.
- 4.2 The volume dampers shall be of an approved type, lever operated and completed with locking devices which will permit the dampers to be adjusted and locked in any positions and clearly indicating the damper position.
- 4.3 The dampers shall be of splitter, butterfly or louver type. The damper blade shall not be less than 1.25 MM (18) Gauge, reinforced with 25 MM angles 3 MM thick along any unsupported side longer than 250 MM. Angles shall not interfere with the operation of dampers, nor cause any turbulence.
- 4.4 Automatic and manual volume opposed blade dampers shall be completed with frames and bronze bearings as per drawings. Dampers and frames shall be constructed of 1.6 MM steel sheets and blades shall not be over 225 MM wide. The dampers for fresh air inlet shall additionally be provided with fly mesh screen, on the outside, of 0.8 MM thickness with fine mesh.
- 4.5 Wherever require for system balancing, a volume balancing opposed blade damper with quadrant and thumb screw lock shall be provided.
- 4.6 After completion of the duct work, dampers are to be adjusted and set to deliver air flow as specified on the drawings.

#### 5. **Fire Dampers**

- 5.1 Automatic fire dampers shall be provided wherever shown on the drawings. The damper shall be multi blade louvre type. The blades should remain in the air stream in open position and shall be constructed with minimum 1.8 MM thick galvanised sheets. The frame shall be of 1.6 MM thickness. Other materials shall include locking device, motorised actuator, control panel to trip AHU motor etc.
- 5.2 The fire dampers shall be capable of operating automatically on receiving signal from a fire alarm panel. All control wiring shall be provided between fire damper and electric panel.

#### 6. **Access panel**

6.1 A hinged and gasketed access panel measuring at least 450 MM x 450 MM shall be provided on duct work before each reheat coil and at each control device that may be located inside the duct work.

7. **Miscellaneous**

7.1 All duct work joints are to be true right angle and with all sharp edges removed.

7.2 Sponge rubber gaskets also to be provided behind the flange of all grilles.

7.3 Each chute from the duct, leading to a grille, shall be provided with an air deflector to divert the air into the grille through the shoot.

7.4 Diverting vanes must be provided at the bends exceeding 600 MM and at branches connected into the main duct without a neck.

7.5 Proper hangers and supports should be provided to hold the duct rigidly, to keep them straight and to avoid vibrations. Additional supports are to be provided where required for rigidity or as directed by Engineer-In-Charge.

7.6 The ducts should be routed directly with a minimum of directional change.

7.7 The duct work shall be provided with additional supports/hangers, wherever required or as directed by the Engineer-In-Charge, at no extra cost.

7.8 All angle iron flanges to be welded electrically and holes to be drilled.

7.9 All the angle iron flanges to be connected to the GSS ducts by rivets at 100 MM centres.

7.10 All the flanged joints, to have a sponge rubber packing stuck to the flanges with suitable adhesive.

7.11 The G.S.S. ducts should be lapped 6 MM across the flanges.

7.12 The ducts should be supported by approved type supports at a distance not exceeding 2.0 Metres.

8. **Standard Grilles**

8.1 The supply and return air grilles shall be fabricated from extruded aluminium sections. The supply air grilles shall have single/double louvers. The front horizontal louvers shall be of extruded section, fixed/adjustable type. The rear vertical louvers where required shall be of aluminium extruded sections and adjustable type. The return air grille shall have single horizontal extruded section fixed louvers. The grilles may or may not be with an outer frame.

8.2 The damper blades shall also be of extruded aluminium sections. The grill flange shall be fabricated out of aluminium extruded section. Grilles longer than 450 MM shall have intermediate supports for the horizontal louvers.

9. **Diffusers**

9.1 The ceiling type square diffusers shall be of aluminium extruded sections with flush or step down face, as specified with fixed pattern and neck.

9.2 All supply diffusers shall be provided with extruded aluminium dampers, with arrangement for adjustment from the bottom.

- 9.3 The slot diffusers shall be of aluminium extruded sections with diffusion plate and sliding damper.
10. **Linear Diffusers/Grilles**
- 10.1 The linear diffusers/grilles shall be fabricated from Aluminium extruded sections.
- 10.2 The diffusion blades shall be extruded, flush mounted type with single or double direction air flow.
- 10.3 The frame shall be of aluminium extruded section and shall hold the louvers tightly in fixed position.
- 10.4 The dampers as described under grilles shall be provided wherever specified.
11. **Exhaust Grilles**
- 11.1 The exhaust grilles shall be fabricated from aluminium extruded sections.
- 11.2 The exhaust grilles shall be horizontal fixed bar grilles with 15<sup>0</sup> blade inclination.
12. **Sensor Terminal**
- 12.1 Sensor mounting terminal with cap shall be provided for taking temperature, pressure or other measurement in ducts or AHUs.
- 12.2 The terminal shall be fabricated from gun metal stock, duly threaded with check nut, nut and washers.
13. **Painting and Vision Barrier**
- 13.1 All grilles, and diffusers shall be powder coated, before installation, in approved colour.
- 13.2 All ducts immediately behind the grilles/diffusers etc. are to be given two coats of black paint in matt finish.
- 13.3 The return air and dummy portion of all linear grilles shall be provided with a vision barrier made of 24 gauge galvanized sheets. The vision barrier shall be fixed to the false ceiling frame with self tapping screws and shall be given two coats of black paint in matt finish. Care shall be taken to ensure that the return air path is not obstructed.
14. **Testing**
- 14.1 After completion, all duct system shall be tested for air leakage.
- 14.2 The entire air distribution system shall be balanced to supply the air quantity as required in various areas and the final tabulation of air quantity through each outlet shall be submitted to the Engineer-In-Charge for approval.

\*\*\*\*\*

### **Section 3: PIPE WORK**

#### **1. General**

All piping work shall conform to quality standards and shall be carried out as per specifications and details given hereunder & shall follow the applicable on relevant Indian standards.

#### **2. Pipes**

2.1 All pipes upto 150 MM shall be M.S. E.R.W tube (black steel) heavy class as per I.S. 1239-79, Part-I with amendment-I of January '81.

#### **3. Fittings**

3.1 The dimensions of the fittings shall conform to I.S.1239/69 Part-II unless otherwise indicated, in the specifications.

3.2 All bends in sizes upto and including 150 MM dia. shall be readymade of heavy duty, wrought steel of appropriate class.

3.3 All bends in sizes 200 MM and larger dia. shall be fabricated from pipes of the same dia. and thickness, with a minimum of 4 sections, and having a minimum centre line radius of 1.5 diameter of pipes.

3.4 All fittings such as branches reducers etc. in all sizes shall be fabricated from pipes of the same Dia. and thickness, and its length should be at least twice the dia. of the pipe.

3.5 The branches may be Butt welded straight to the main line, without making a separate fitting, where specified on drawings or required by Engineer-In-Charge.

3.6 Blank ends are to be formed with flanged joints and 6 MM thick blank insertion of rubber gasket between flange pair for 150 mm and over, in case where, a future extension is to be made otherwise blank end discs of 6 mm thickness are to be welded on, with additional cross stiffeners from 50 mm x 50 mm M.S. Heavy angles, for sizes upto 350 MM dia. All ends larger than 400 MM dia. shall have dished ends.

#### **4. Flanges**

4.1 All flanges shall be of mild steel as per I.S. 6392/71 and shall be steel slip-on-type, welded to the pipes, flange thickness shall be as per BS10.

4.2 Flanges may be tack welded into position, but all final welding shall be done with joints dismantled. 3 mm thick gaskets shall be used with all flanged joints. The gaskets shall be fibre re-inforced rubber as approved by the Engineer-In-Charge. Special adhesive compound shall be used between flanges of steam, air and gas lines.

4.3 Flanges shall be used as follows :-

4.3.1 Counter flanges for equipment having flanged connections.

4.3.2 Flanged pairs shall be used on all such equipment, which may require to be isolated or removed for service e.g. Pumps, refrigeration machines, air handling units etc.

4.3.3 All threaded valves shall be provided with nipples and flanged pairs on both sides to permit flange connections, for removal of valves from main lines for repair/replacement.

#### **5. Valves**

## 5.1 **Butterfly Valves**

- 5.1.1 The butterfly valve shall consist of cast iron body preferably in two piece construction.
- 5.1.2 The disc shall consist of disc pivot and driving stem shall be in one piece centrally located.
- 5.1.3 The valve seat shall be synthetic material suitable for water duty. It shall line the whole body.
- 5.1.4 The disc should move in slide bearings on both ends with 'o' ring to prevent leakage.
- 5.1.5 The handle should have arrangement for locking in any set position.
- 5.1.6 All valves 200mm Dia. and above shall be gear operated.
- 5.1.7 The valve should be suitable for 12 Kg/cm<sup>2</sup> working pressure.

## 6. **Ball Valves**

- 6.1 All Valves 40 mm Dia. and below shall be of Gun Metal Ball type Valves with (FPT) female threads conforming to class 2 of IS 778 and mating flanges fitting.
- 6.2 All Ball valves shall be ISI Marked.

## 7. **Balancing Valves**

- 7.1 The balancing valves upto 80 mm Dia. shall be of gunmetal screwed type conforming to BS 5154 or equivalent specifications.
- 7.2 The valve shall be cast gunmetal ASTM B-62 and complete with non rising spindle. PTFE disc seal cast metal hand wheel.
- 7.3 The port opening shall permit precise regulation of flow rate, by accurately measuring the pressure drop across the port.
- 7.4 The valve shall be completed with two ports for connections to a mercury manometer, to measure the pressure drop, as well as a drain port.
- 7.5 The spindle shall have a shielded screw to set the flow at the desired level.
- 7.6 This valve shall be used wherever specified.

## 8. **Dual Plate Check Valves**

- 8.1 The body of the check valve shall be made from a single piece casting in cylindrical shape.
- 8.2 There shall be two plate, which shall be hinged in the centre of the circle. Both plates shall be have springs attached to them for assisting in closing action of the valve.
- 8.3 There shall be properly/designed metal to metal seal between the plates and the outer body, to ensure non leaking sealing.
- 8.4 The valve design shall confirm to API 594 or equivalent specifications.

## 9. **Automatic/Dynamic Balancing Valve.**

- 9.1 Automatic Dynamic Balancing Valve shall be of forged brass (upto 40mm dia.) grey iron (above 40mm dia.) construction of 1350K Pa pressure and 120°C temperature rating. The valves shall have

precision calibrated, stainless steel carriage to achieve the desired/pre-fixed flow rates irrespective of the pressure fluctuations in the water lines within a range of 10-210 K. Pa. The flow rate within a tolerance of  $\pm 5\%$  will be achieved by automatic adjustment of the open orifice area in response to the pressure differential changes. The end connection upto 80mm dia. should be threaded and for above 80mm dia. it should be flanged.

#### 10. **Strainers**

- 10.1 The strainers shall either be pot type or 'Y' type with cast iron or fabricated steel body, tested upto pressure applicable for the valves as shown on the drawings.
- 10.2 The strainers shall have a perforated bronze sheet screen with 3 mm perforation and with a permanent magnet, to catch iron fillings.
- 10.3 Pot strainers shall be provided with flanged connections and 'Y' strainers shall be provided with flanged ends.
- 10.4 The strainers shall be designed to facilitate easy removal of filter screen for cleaning, without disconnection of pipe line.

#### 11. **Other Valves**

- 11.1 All gauge cocks shall be of gunmetal plug type, complete with siphon (brass chrome plated).
- 11.2 All drain valves shall be of gunmetal with a hose union connection on one hand.

#### 12. **'V' Form Thermometers (Industrial Type)**

- 12.1 The body shall be of aluminium alloy with anodized gold colored surface. The casing shall be adjustable side ways for reading from the front. The glass capillary shall be triangular in shape with the blue mercury filled in glass. Scale of reading shall be of the range  $0^{\circ}\text{C}$  to  $50^{\circ}\text{C}/32^{\circ}\text{F}$  to  $120^{\circ}\text{F}$ .
- 12.2 Thermometer shall be suitable for 12 mm connections with long stem, so that thermometer is removable without damaging the insulation. M.S. socket to be welded on pipes shall be provided with thermometer.

#### 13. **Jointing**

- 13.1 All pipe lines shall be welded type.
- 13.2 Square cut plain ends will be welded for pipes upto and including 100 MM Dia.
- 13.3 All pipes 125 MM Dia. or larger will be bevelled by 35 DEG. before welding.

#### 14. **Pipe Supports/Hangers**

- 14.1 Pipe supports shall be provided and installed for all piping wherever indicated, required or otherwise specified. Wherever necessary, additional hangers and supports shall be provided to prevent vibration or excessive deflection of piping and tubing.
- 14.2 All vertical pipe support shall be made of 10mm M.S. Rods and the horizontal support shall be of M.S. angles of 50x50x4 mm thick.
- 14.3 Pipe supports shall be adjustable for height and prime coated with rust preventive paint & finish coated with black paint using approved grade of paint.

The spacing of pipe supports shall not be more than that specified below :-

<u>Nominal pipe size MM</u>	<u>Spacing (Metres)</u>		
15	...	...	1.25
20 & 25		...	2.00
32,30,50 & 65		...	2.50
80,100 & 125		...	2.50
150 & Above		...	3.00

- 14.4 Extra supports shall be provided at the bends and at heavy fittings like valves to avoid undue stresses on the pipes. Pipe hangers shall be fixed on wall and ceiling by means of approved metallic dash fasteners.
- 14.5 Insulated piping shall be supported in such a manner as not to put undue pressure on the insulation, cause condensation. The pipe supports or Saddles shall be of PUF, factory fabricated to suit pipe sizes.
- 14.6 Hangers shall be supported from structural steel, concrete inserts & pipe racks, as specifically approved.
- 14.7 No hangers shall be secured to underside of light weight roof decking and light weight floor glass.
- 14.8 Mechanical equipment shall be suspended midway between steel joints and panel points.
- 14.9 Drilling or punching of holes in steel joint members will not be permitted.
- 14.10 Contractor shall make shop drawing for fixing of support for approval.
15. **Miscellaneous**
- 15.1 Provide all pipe work as required to make the apparatus connected complete and ready for regular and safe operation. Unless otherwise noted, connect all apparatus and equipment in accordance with manufacturer's standard details, as approved by Engineer-In-Charge.
- 15.2 Provide valves and capped connections for all low points in piping system, where necessary or required for draining systems. Provide Isolating valves & Drain valves in all risers to permit repairs without interfering with the rest of the system.
- 15.3 During construction, temporarily close, open ends of pipes with sheet metal caps, where necessary, or required to prevent debris from entering the piping system.
- 15.4 Support piping independently of all equipment so that the equipment is not stressed by the piping weight or expansion.
- 15.5 To facilitate the maintenance, repair and replacement:
- 15.5.1 Provide shut-off valves where indicated and for individual equipment, units at inlet and outlet, to permit unit removal for repairs, without interfering with the remainder of the system. Additional shut-off valves shall be provided as required to enable all systems to be fully sectionalized. Bypass and stop valves shall be provided for all automatic control valves as specified.
- 15.5.2 Arrange piping for maximum accessibility for maintenance and repair, locate valves for easy access and operation. No valves shall be installed with handles pointing down, unless unavoidable.

15.5.3 Cut the pipes accurately according to measurements, established at building site & work into place without springing or forging.

15.5.4 Where pipes are to be buried under ground, they should be coated with one coat of bituminous paint. The top of the pipes shall not be less than 75 CM. from the ground level. Where this is not practical permission of Engineer-In-Charge shall be obtained for burying the pipes at lesser depth. The pipes shall be surrounded on all sides by sand cushions of not less than 15 CM. After the pipes have been laid and top sand cushions provided, the trench shall be refilled with the excavated soil, excess soil shall be removed from the site of work by the contractor.

16. **Sleeves**

16.1 Where pipes pass through floors, walls, etc provide Galvanized steel pipe sleeves 50 MM larger than outside diameter of pipe. Where pipes are insulated, sleeves shall be large enough to ample clearance for insulation.

16.2 Where pipes pass through outside walls or foundations, the space between pipe and sleeve shall be filled with rock wool covered with GI sheet.

16.3 The centre of pipes shall be in the centre of sleeves, and sleeves shall be flushed with the finished surface.

17. **Arrangement and alignment of piping**

17.1 All piping shall be arranged and aligned in accordance with the drawings as specified. Where special conditions are encountered in the field, the arrangement and alignment of piping shall be as directed by the Engineer-In-Charge.

17.2 The piping shall be installed in a uniform manner, parallel or perpendicular to walls or ceilings, and all changes in directions shall be made with fittings. The horizontal piping shall be run at right angles and shall not run diagonally across rooms or other piping. wherever possible all piping shall be arranged to provide maximum head room.

17.3 All piping shall be installed as directly as possible between connecting points in so far as the work of other trades permits. Where interference occurs with another trade whose work is more difficult to route, this contractor shall reroute his pipes as required to avoid interference, at the discretion of the Engineer-In-Charge.

17.4 All piping shall be carefully installed to provide for proper alignment, slope and expansion.

17.5 The stresses in pipe lines shall be guided and pipes shall be supported in such a manner that pipe lines shall not creep, sag or buckle.

17.6 Anchors and supports shall be provided wherever necessary to prevent any misalignment of piping.

17.7 Small tubing gauges, controls or other equipment installed on any apparatus, shall not be coiled nor excessive in length, but shall be installed neatly, carefully bent at all changes in direction, secured in place and properly fastened to equipment at intervals to prevent sagging.

17.8 The piping shall be grouped wherever practical and shall be installed uniformly in straight parallel lines in either vertical or horizontal positions.

18. **Testing**

18.1 In general, tests shall be applied to piping before connection of equipment and appliances. In no case shall the piping, equipment or appliances be subjected to pressures exceeding their test ratings.



- 18.2 The tests shall be completed and approved before any insulation is applied. Testing of segments of pipe work will be permitted, provided all open ends are first closed, by blankoffs or flanges.
- 18.3 After tests have been completed the system shall be drained and flushed 3 to 4 times and cleaned of all dust and foreign matter. All strainers, valves and fittings shall be cleaned of all dirt, fillings and debris.
- 18.4 All piping shall be tested to hydraulic test pressure of at least one and half times the maximum operating pressure but not less than 10 kg/cm<sup>2</sup> for a period of not less than 12 hours. All leaks and defects in the joints revealed during the testing shall be rectified to the satisfaction of the Engineer-In-Charge, without any extra cost.
- 18.5 All the piping systems shall be tested in the presence of the Engineer-In-Charge or their authorized representative. Advance notice of test dates shall be given and all equipments, labour, materials required for inspection, and repairs during the test shall be provided by the contractor. A test shall be repeated till the entire systems are found to be satisfactory to the above authority. The tests shall be carried out for a part of work if required by Engineer-In-Charge in order to avoid hindrance in the work of the insulation contractor.
- 18.6 Miscellaneous piping, tests with air at 10.5 kg/cm<sup>2</sup> for a minimum of 24 hours without drop in pressure.
- 18.7 The contractor shall make sure that proper noiseless circulation is achieved through all piping systems. If due to poor bond, proper circulation is not achieved, the contractor shall bear all expenses for carrying out the rectification work including finishing of floors, walls and ceiling damaged in the process of rectifications.
- 18.8 The contractor shall provide all labours and materials to make provision for removing water and throwing it at the proper place, during the testing or/and after the testing to avoid damages to employer or other contractors' properties. Any damages caused by the contractor to the employer or other contractors' properties, shall be borne by the contractor.
19. **Drain Piping**
- 19.1 The drain piping shall be medium class galvanised steel as per IS 1239/1979.
- 19.2 The fittings shall be of 'R' brand or "Unik" or equal forged with screwed connections.
- 19.3 The gate valves shall be of gun metal duly ISI marked on each valve.
- 19.4 Pipe crosses shall be provided at bends, to permit easy cleaning of drain line.
- 19.5 The drain line shall be provided upto the nearest drain trap and pitched towards the trap.
- 19.6 Drain lines shall be provided at all the lowest points in the system, as well as at equipments, where leakage of water is likely to occur, or to remove condensate and water from pump glands.
20. **Painting**
- 20.1 All pipes supports, hangers, etc., shall be given two coats of red oxide primer.
- 20.2 All pipes, which are not to be insulated, shall then be given two coat of finish paint, of a type and colour, as approved by the Engineer-In-Charge.

\*\*\*\*\*

## **Section 4: INSULATION**

### **1. General**

The Insulation of water piping, air handling units, ducting, chillers & refrigerant piping etc., shall be carried out as per specifications given below:

### **2. Materials**

The materials to be used for insulation shall be as follows, unless some other material is specifically mentioned elsewhere. The detailed specifications of the materials are listed under respective sub heads.

2.1	Pipe Insulation	:	Rigid Polyurethane Foam (PUF)
2.2	Drain Pipe Insulation	:	Polyethylene Foam (Kinney Foam)
2.3	Duct Insulation	:	Resin Bonded glasswool
2.4	Acoustic Treatment	:	Resin Bonded glasswool
2.5	Equipment Insulation	:	Expanded Polystyrene (SE) (EP).
2.6	Refrigerant Pipe	:	Nitrile rubber insulation

### **3. Pipe Insulation**

3.1 The insulation for chilled water and drain piping, chillers, pump etc. shall be carried out from rigid polyurethane foam having a 'K' value of 0.018 W/mK. at mean temperature of 10°C and a density of 27.2 to 39.9 kgs/cubm. The material shall be factory faced on one side with aluminium foil on the outside, reinforced with kraft paper and fused to the insulation material. The aluminium foil shall be extended by a minimum of 50 mm on one side of the pipe section along the length to seal all longitudinal joints.

The aluminium foil facing shall be replaced with Kraft Paper facing wherever the pipe is to be covered with Tar felt.

3.1.2 The thickness of the insulation for chilled water pipes shall be 30 MM.

3.1.3 Preformed pipe sections shall be used for pipes upto and including 350 mm dia.

3.1.4 Pipes above 350 mm dia. shall be insulated with insulation slabs cut in mitred sections.

### **3.2 Drain Pipe Insulation**

3.2.1 The material for insulation of drain pipes shall be sheets of Polyethelene foam having a 'K' valve of 0.027 W/mK at a mean temperature of 10°C and a minimum density of 26 Kg./cubm.

3.2.2 The thickness of insulation shall be 2 layer of 6 mm thickness..

### **3.3 Duct Insulation**

3.3.1 The materials for duct insulation shall be resin bonded fibre glass, as described earlier but conforming to I.S. 8183 of 1976. The density of insulation shall not be less than 24 kg/cubm and material shall be in the form of blankets/rolls of uniform thickness. The 'K' value at 10° C. Shall not be less than 0.031 W/mK. It shall be factory faced with aluminium foil on one side reinforced with kraft paper and fused to the insulation material.

3.3.2 The thickness of duct insulation shall be as follows:

- a. Duct in conditioned space - 25 mm thick
- b. Duct in unconditioned space - 50 mm thick

### 3.4 **Acoustic Treatment**

- 3.4.1 The material for acoustic treatment of ducts, rooms, roofs etc. shall be resin bonded fibre glass, as described earlier, conforming to I.S. 8183 of 1976. The density of fibre glass shall be 32 kg/cub.m and the material shall be in the form of boards of uniform density. The 'k' value at 10°C shall not be less than 0.03 W/mK. Facing shall be provided with 0.5 mm perforated aluminum sheet held with G.I. Nuts bolts or nailed to the batten work as required.
- 3.4.2 The thickness of insulation shall be as follow unless otherwise specified elsewhere :
- a. Duct Acoustic : 25 MM
  - b. Room Acoustic : 50 MM

### 3.5 **Equipment Insulation**

- 3.5.1 The materials for equipment insulation shall be slabs of expanded Polystyrenes (Self extinguishing grade) having a 'K' Value of 0.035 W/mK at 10°C and a density not less than 20 Kg./Cum.
- 3.5.2 The complete shell of the chiller as well as its two heads, shall be factory insulated.
- 3.5.3 The insulation on chilled water pumps and expansion tank shall be of expanded polystyrene having a 'K' value of 0.035 W/mK at a mean temperature of 10°C and a density not less than 20 Kg/Cubm. The thickness of the insulation will be as given below :
- I) Expansion tank - 50 mm
  - II) Chilled water pumps - 50 mm

### 3.6 **CPRX Compound**

- 3.6.1 The cold compound adhesive being supplied shall be CPRX Type.

### 3.7 **Tar Felt**

- 3.7.1 The Tar felt used for water proofing shall conform to IS: 1322 Type 3 Grade-I.

## 4. **Installation**

### 4.1 **Chilled Water Piping (PUF)**

- 4.1.1 The pipe shall be thoroughly cleaned with a wire brush and rendered free from all rust and grease.
- 4.1.2 The pipes shall be given a coat of red oxide primer.
- 4.1.3 Two coats of CPRX Compound shall be applied on the cleaned pipe surface.
- 4.1.4 The preformed sections of insulation shall be fixed tightly to the surface taking care to seal all joints.
- 4.1.5 All joints along the circumference of the pipe sections shall be sealed with 50 mm wide aluminium faced adhesive tape.
- 4.1.6 All longitudinal joints shall be further sealed with 50 mm wide aluminium faced adhesive tape.
- 4.1.7 Insulation on pipes and valves in the AHU room shall be covered with 0.5 mm aluminium sheet cladding.

## 4.2 **Drain Piping**

- 4.2.1 The pipe shall be thoroughly cleaned with a wire brush and rendered free from all rust and grease.
- 4.2.2 Coat the pipe with one layer of red oxide primer.
- 4.2.3 Then two layer of 6mm thick insulation shall be wrapped on the pipe.
- 4.2.4 Then it shall be tied with 1 mm thick G.I. wires.

## 4.3 **Ducting**

- 4.3.1 Clean the surface with a wire brush and make it free from rust and oil.
- 4.3.2 Apply two coats of CPRX compound on the cleaned surface.
- 4.3.3 Wrap the duct with insulation blankets of the thickness mentioned in item 3.3.2 above and covered with 0.63 mm/19 mm wire mesh netting on the outside.
- 4.3.4 The joints shall be sealed with aluminum tape before covering with wire netting.
- 4.3.5 The Ducts in areas exposed to the weather shall be additionally covered with one layer of tar felt B.H. The tar felt shall be stuck with Hot Bitumen.

## 4.4 **Duct Acoustic Lining**

- 4.4.1 The duct surface shall first be cleaned from inside.
- 4.4.2 Then 25 mm square section made of 18 Ga (1.2 mm) thick G.I. sheet should be fixed on both ends of the duct piece.
- 4.4.3 The insulation slabs should be fixed between these sections of ducts using adhesive compound and **stick pins**.
- 4.4.4 The insulation shall the be covered with RP tissue, sealing all joint so that no fibre is visible.
- 4.4.5 The insulation shall then be covered with 0.5 mm perforated aluminium sheets.
- 4.4.6 The sheet of insulation shall be secured to the duct by means of stick pins as mentioned above.

## 4.5 **Equipment**

- 4.5.1 The surface shall first be cleaned with wire brush.
- 4.5.2 Then two layers of hot bitumen shall be applied.
- 4.5.3 The insulation shall then be fixed in one layer and sealing them with hot bitumen.
- 4.5.4 The insulation shall then be covered with 0.63 mm/ 19 mm mesh wire netting which shall be fixed to the insulation with brass 'U' nails.
- 4.5.5 The final finish shall be 0.50 mm aluminium cladding.

## 4.6 **Room Acoustic**

- 4.6.1 Fix 40 mm x 50 mm G.I. channels at 0.5 metre interval longitudinally then fix cross battens at 1.0 metre centre using suitable gutties, and brass screws.
- 4.6.2 Fill each rectangle with 50 mm glass wool and covered with RP tissue.
- 4.6.3 Tie with 24 gauge G.I. Wires at 300 mm intervals.
- 4.6.4 Then cover with 22 gauge (0.80 mm) perforated Aluminium sheet having 3 mm perforations at 6 mm centres. Overlap all joints and provide beading of 25 mm by 2 mm flats.
- 4.6.5 All corners joints shall be covered with 25 x 25 x 2 mm thick aluminium angles.

\*\*\*\*\*

## **Section 5:**

## **ELECTRIC CABLING**

### **1. General**

The electric cable connections of motors and earthing of all equipments shall be carried out, as per specifications, given hereunder.

### **2. Cabling**

2.1 The cabling of various equipment shall be carried using PVC Insulated and armoured cables.

2.2 The PVC armoured power cable for use on 415 volts system shall be 3 or 3.5 Core with aluminium conductors and be of 660/1100 volts grade, as per IS 1554 (Part I) 1964. The cross section of the cable shall be to suit the load and rating of the equipment. The cables shall be of aluminium conductor, PVC insulated, strip armoured with overall PVC sheathing.

2.2.1 The cables shall be laid as per IS-1255/1967, Indian standard code of practice.

2.2.2 The cables shall be laid, as per drawings in the ducts/pipes/trays etc. along a short and convenient route between switch board and the equipment, (either in trenches, on wall or on hangers, supported from the slab). Cable routing shall be checked at the site of work to avoid interference with structure, equipment etc. Where more than one cables are running close to each other, proper spacing should be provided between them.

2.2.3 The radius of bends of the cable should not be less than 12 times the overall dia. of cable in order to prevent undue stress and damage at the bends, the cables should be supported with wooden cleats on M.S. Supports, when laid in trenches, or wall/ceiling suspended hangers. When laid under ground the cables should be covered with fine soft earth and protected with 2nd Class bricks. Suitable G.I. Pipe shall be used wherever cables are laid under the roads etc.

2.2.4 Wooden bushes shall be provided at the ends of pipes through which cables are connected through.

### **3. Surface Wiring**

3.1 The surface wiring shall be cased in conduits which shall be of 1100 volts grade and conform to IS 9587-1987 (revised to date)

3.1.1 The conduits used shall be of high quality & all joints shall be made with sockets. The bends and elbows shall have inspection covers fixed with grease free screws. The joints shall be water tight. Approved metal saddles shall be used to secure the exposed conduits at a space of 1 meter or less. The connection of the conduits to switches etc., shall be secured by check nuts and ebonite bushes provided at the ends of conduits.

3.1.2 The M.S. conduits shall be heavy duty and rigid type-ISI marked/conforming to IS specifications. The wall thickness shall not be less than 2 mm. For conduits above 32 mm dia. Metallic conduits of 19 mm dia. and below shall not be used. Conduit accessories (Boxes etc.) shall conform to IS-5133-1968 and IS-2667-64 (amended-revised to date). Conduit pipes shall be jointed, wherever necessary by means of screwed couplers and screwed accessories only. In Long distance straight, run of conduits inspection type couplers at suitable intervals shall be provided.

3.1.2 Threads on conduit pipes shall be between 13 mm to 19 mm long.

3.1.4 The wiring shall be carried-out as per IS 732-1989 (Amended and revised to date).

3.2 Flush inspection covers shall be provided in case of Concealed, recessed conduits. The staples for the conduits shall not be spaced more than 0.60 meters apart. Before filling up the chase with concrete the conduits should be given a coat of rust proof paint.

3.3 The wires shall be drawn only after all the conduits have been properly fixed in position. Fish wires (steel wire : 16 SWG) shall be laid in conduits for drawing of wires subsequently.

4. **Control Cabling/wiring**

4.1 Control cables shall be 1100 volts grade, as per IS 1554, made from copper conductor of 1.5 Sq mm PVC insulated single Core, strip armoured with an overall PVC sheathing.

4.2 The cables and conduits wiring shall be carried out as per details given under 2.2 and 2.3 above.

5. **Earthing**

5.1 All equipment connected with electric supply shall also be provided with double earthing continuity conductors. The size of G.I. earthing conductors shall be :-

<b>Size of phase wire sq.mm Aluminium</b>	<b>Size of G.I. conductor Tape/Wire (Swg)</b>
185	25 mm x 6 mm (strip)
150	25 mm x 6 mm (strip)
120	25 mm x 6 mm (strip)
95	4 Swg
70	4 Swg
50	6 Swg
35	6 Swg
25-6	6 Swg
4	6 Swg

Note :- Aluminium earthing conductors of equivalent Size may be used in lieu of GSS conductors mentioned above.

6. **Miscellaneous**

6.1 The final connections to the equipment shall be through Flexible connections in case of conduit wiring and also where the equipment is likely to be moved back and forth, such as on slide rails.

6.2 An isolator switch shall be provided at any motor which is separated from the main switch panel by a wall or partition or other barrier or is more than 15 metres away from the main panel.

6.3 Two separate and distinct earthing conductors shall be Connected from the equipment upto the main switch board panel.

6.4 The branch lines from the main panel to each equipment shall be separated and should not criss cross other lines.

6.5 The entire installation shall be tested as per Electricity rules and I.S.S. 732-1973 with amendments 1,2&3 prior to the commissioning of the plant and a suitable test report furnished by a competent and authorized person. The test report will be obtain by contractor himself at his own expenses.

6.6 All exposed switch board panels, conduits, hangers etc. shall be given 2 coats of suitable paint of approved colour, when all work has been completed.

\*\*\*\*\*

## **Section 6: TESTING AND COMMISSIONING**

### **1. General**

- 1.1 The contractor must perform all inspection and tests of the system as a whole and of components individually as required, under the supervision of the architect, in accordance with the provisions of the applicable ASHRAE standards or approved equal in addition to furnish necessary test certificates from manufacturers.
- 1.2 The system shall then be commissioned, tested and balanced to fulfil the intent and purpose for which it is designed.
- 1.3 In addition continuous Run Tests shall be carried out during peak weather condition.

### **2. Compressors Condensers/Chillers/Evaporators/Pumps etc.**

- 2.1 Hydraulic test for various components and assembled equipments at 1.5 times design pressure or double the operating pressure, whichever is higher.
- 2.2 Pneumatic leak test after assemblies at design pressure
- 2.3 Static and dynamic balancing on electronic precision machine for rotating parts, links, impellor/ crank shaft assemblies etc.
- 2.4 Testing of oil passages in compressor at 1.5 times pump discharge pressure.
- 2.5 Pressure drop test for condenser, chiller and evaporator.
- 2.6 For compressor assembly, electronic leak, air running test, pneumatic test with dry nitrogen and leak test in water.

### **3. Air Handling Units**

#### **3.1 Blowers**

- 3.1.1 Dynamic/static balancing of impellers.
- 3.1.2 Performance test as per applicable codes.

#### **3.2 Coils**

- 3.2.1 Pneumatic test.

#### **3.3 Filters**

- 3.3.1 Test of filter elements as per B.S. 2831 B.S. 1701 as applicable. This is to ascertain filtration efficiency by weight at inlet and outlet.
- 3.3.2 Manufacturer's test certificates also to be produced for the assembled A.H.U. Final dimensional check will be done. Inspection may be done during assembly of components for quality of workmanship, painting etc.

#### **3.4 Piping**

Materials check for specifications and size.

#### **3.5 Valves**

Hydraulic./pneumatic test certificates.

#### **3.6 Motors**

Manufacturer's test certificate as per motor data sheet.

3.7 **Instruments and Controls**

Visual examination.

3.8 **Special Note**

Vendor to note that above procedure is to be followed in addition to the specifications attached with the tender.

4. **Associated Works at Site.**

- 4.1 All electrical items will be subjected to inspection at any stage during manufacturing activity. Routine electrical test as per relevant codes. Inspection of manufacturer's test certificates.
- 4.2 Inspection of raw materials to be used for fabrication and assembly and inspection of manufacturer's certificates.
- 4.3 Inspection of welding including welders qualification as desired by inspection engineers. Inspection of fabricated items.
- 4.4 Pressure testing of pipe fittings used for the refrigerant and water and other services.
- 4.5 Pressure testing, leak testing of complete piping network for chilled water. (Condenser water and refrigerant/services).
- 4.6 Checking of electrical circuits (power & controls) and checking functioning of controls of refrigerant systems and other circuits of air conditioning plant.
- 4.7 Checking of calibration of controls and instrumentation
- 4.8. Checking of assemblies or electrical control panel, instruments panels, local panels (dimensional and functional) enunciator panels etc.
- 4.9 Inspection of complete electrical installation at site.
- 4.10 Performance testing of complete A.C. Plant as per specifications.

5. **Vendor Responsibility**

- 5.1 The above inspection procedure is given for general guidance and information of vendors. The inspection of purchaser/consultant is strictly not limited to these.
- 5.2 The inspection engineer of purchaser/consultant will have full right, to have detailed inspection at any stage right from placement of order to completion of project, as and when desired by inspection engineer.
- 5.3 Co-ordination of inspection agency of purchaser/consultant with his factory/subvendor's factory/erection site will be the sole responsibility of successful vendor, subsequent to placement of order for complete air conditioning plant, covered under these technical specifications.

6. **Piping System**



6.1 In general pressure tests shall be applied to piping only before connection of equipment and appliances. In no case shall piping, equipment or appliances be subjected to pressure exceeding their test ratings.

6.2 Tests shall be completed and approved before any insulation is applied.

6.3 After tests have been completed, the system shall be drained and cleaned of all dust and foreign matter. All strainers, valves and fittings shall be cleaned of all dirt, fittings, and debris.

6.4 **Water Piping**

All water piping shall be tested and proven tight under Hydrostatic pressure of 11 Kg/Cm<sup>2</sup> (150 PSI) or 1.5 times the design pressure which ever is more unless stated otherwise in the specifications. The prescribed pressure shall be maintained for eight hours. In case leaks are detected, the pressure test will be repeated, after the repair of the leaks.

7. **Duct Work**

7.1 All branches and outlets shall be tested for air quantity, and the total of the air quantities shall be within plus five percent (5%) of fan capacity.

7.2 Fire dampers, volume dampers and splitter dampers shall be tested for proper operation.

8. **Electrical Equipment**

8.1 All electrical equipment shall be cleaned and adjusted on site before application of power.

8.2 The following tests shall be carried out :

8.2.1 Cables and Wires continuity tests.

8.2.2 Insulation resistance tests, phase to phase and phase to earth, on all circuits and equipment, using a 500 Volts meggar. The meggar reading shall be not less than one mega ohm.

8.2.3 Earth resistance between conduit system and earth must not exceed half (1/2) CMH.

8.2.4 Phasing out and phase rotation tests.

8.2.5 Operating tests on all protective relays to prove their correct operation before energizing the main equipment.

8.2.6 Operating tests on all starters, circuit breakers etc.

9. **Plant Audit & Certification work**

9.1 The work of plant audit & certification shall be done by an approved outside agency.

9.2 The whole system balancing shall be tested with microprocessor based Hi-tech instruments with an accuracy of  $\pm 0.5\%$ .

9.3 The instrument shall be capable of storing data and then down loading into a PC. The agency shall provide a minimum but not limited to the following instruments.

9.3.1 Microprocessor based velocity calculation meter to measure DB and WB temperature, RH and dew point.

9.3.2 Velocicalc meter to measure air volume and air velocity.

- 9.3.3 Pitot tube.
- 9.3.4 Electronic Rotary Vane Anemometer.
- 9.3.5 Accubalance Flow Measuring Hood.
- 9.4 The outside agency shall analyse all the data and shall be responsible for the capacity and performance audit and certification of the plant.
- 9.5 The successful Bidder shall be responsible to provide necessary sockets and connections for fixing of the Testing Instruments, probes etc.

10. **Commissioning of the System**

The system shall be commissioned by adopting the following procedure.

- 10.1 The installation as a whole shall be balanced and tested upon completion, and all relevant information, including the following shall be submitted to the architects.
  - 10.1.1 Air volume passing through each unit, duct, grilles, apertures.
  - 10.1.2 Static pressure in each air duct.
  - 10.1.3 Water flow passing through each condenser, chiller, AHU etc.
  - 10.1.4 Differential pressure readings across each filter, fan and coil, and through each pump.
  - 10.1.5 Electrical current readings, in amperes of full and average load running and starting, together with name plate current of each electrical motor.
  - 10.1.6 Continuous recording over a specified period, of ambient wet and dry bulb temperatures under varying degrees of internal heat loads and use and occupation, in each zone of each part of the building.
- 10.2 Daily records should be maintained of hourly readings, taken under varying degrees of internal heat load and use and occupation, of wet and dry bulb temperatures, upstream "On-Coil" of each cooling coil. Also suction temperatures and pressures for each refrigerating unit. The current and voltage drawn by each machine.
- 10.3 Any other readings shall be taken which may subsequently be specified by the architect.

11. **Air Balancing**

- 11.1 All air handling/ ventilation equipments, duct work and outlets shall be adjusted and balanced to deliver the specified air quantities, at each inlet and outlet as indicated on the drawings.
- 11.2 If these air quantities cannot be delivered without exceeding the speed range of the pulley or the available horse power, the architect shall be notify, before proceeding with the balancing of air distribution system.
- 11.3 A proper record shall be maintained as per Test Proforma given else where.

12. **Water Balancing**

- 12.1 The output of water pumps shall be checked using the balancing valves, provided on the pumps, for this purpose, to ensure the output and pressures match the specified requirement.
- 12.2 Then flow to Condensers/Chillers, Air handling units etc. shall be individually adjusted and balanced to match the flow rate as given in specifications/ drawings to meet the requirement.
- 12.3 The balancing valves, provided on the equipments, shall be used for adjustment.

13. **Miscellaneous**

- 13.1 The above tests and procedures are mentioned herein, for general guidance and information only, but not by way of limitation to the provisions of conditions of contract and specification.
- 13.2 The date of commencement of all tests listed above, shall be subject to the approval of the architect and In accordance with the requirements of this specification.
- 13.3 The contractor shall supply the skilled staff and all necessary instruments and carry out any test of any kind on a piece of equipment, apparatus, part of system or on a complete system, if the architect requests such a test for determining specified or guaranteed data, as given in the specification or on the drawings.
- 13.4 Any damage resulting from the tests shall be repaired and/or damaged material replaced, to the satisfaction of the architect without any extra cost.
- 13.5 In the event of any repair or any adjustment having to be made, other than normal running adjustment, the tests shall be void and shall be recommenced after the adjustment or repairs have been completed.
- 13.6 The contractor must inform the architect when such tests are to be made, giving sufficient notice, in order that the architect or his nominated representative may be present.
- 13.7 Complete records of all tests must be kept and 3 copies of these and location drawings must be furnished to the architect.
- 13.8 The contractor may be required to repeat the test as required, should the Ambient conditions at the time, do not give, in the opinion of the architect, sufficient and suitable indication of the effect and performance of the installation as a whole or of any part, as required.

## **FIRE ALARM SYSTEM**

The scope of work shall include designing, supplying, installing, testing and commissioning of Intelligent Addressable Fire Detection cum Alarm System for Data Centre. This shall conform to relevant latest standards for fire alarm systems (NFPA72/BS5839 as applicable). The control panel, Detectors, other components and accessories required as per the BOQ needs to be installed, tested and commissioned by Vendor to and provide shop drawing to owner's/Consultants / client for approval on the same.

It shall be possible to trip from the Fire Alarm Panel through the use of Addressable Output modules, individual AHU activated by the fire signal of specified detectors.

The equipment shall have UL approved system.

### **1.1. System Description**

The Fire Alarm System shall give Audio/Visual Alarm Signals when - the temperature in Case of Heat Detector or smoke density in case of Smoke Detector, exceeds the pre-set limit.

The system shall give exact location of detector / fire with initiating annunciation like sounder, strobe etc.

The system shall have a facility to give signal to PA system in case of Alarm condition to activate automatic announcement.

The system shall have a microprocessor-based control and monitoring facility. It shall be possible to program each loop with up to minimum 126 Detectors/devices.

Fire alarm control panel shall also have inbuilt Annunciation facility and the panel being able to initiate alarm signal for any particular zone. The system shall be fully supervised for all fault conditions with distinctive alarm operated for fault and fire conditions. Test buttons and software features shall be provided to test the electronic circuits and Detector condition/ health.

The Fire alarm control panel shall be programmable so that when a particular Detector or group of detectors gives a fire signal the Fire alarm control panel should be able to trip PAHUs/ Ventilation fans, access door magnetic contacts and send a signal to the BMS.

In case of Fire in an area the Fire alarm control panel shall be able to trigger a relay that shall shut off the air handling units of that zone through an additional contact provided in the PAHU panel by the AC contractor.

The system shall have a facility to receive signal from suppression system in case of Fire condition to activate Suppression system and send a signal to the BMS.

The system shall have a facility to receive signal from VESDA system and alarm in case of early detection of Smoke/fire and send a signal to the BMS.

The system shall have a facility to receive signal from Water Leak detection system and alarm in case of detection of water and send a signal to the BMS.

*The system shall be based on an open protocol to ensure flexibility.*

## **1.2. Technical Specification**

1.2.1. FIRE ALARM CONTROL PANEL (FACP) : This is a microprocessor-based panel which shall be connected to the various detectors / devices by means of 2 wire loops. The Fire alarm control panel shall be able to supervise individual detectors for proper performance as well as to give pinpoint location of fire alarm.

The panel shall have hooter alarm as well as facility for cutting off of AHUs and Ventilation fans the panel shall also have the facility for integrating with BMS directly or 3<sup>rd</sup> party integration.

The Fire Alarm Control Panel shall be micro processor based fully Intelligent Addressable, Intelligent Control Unit with centralized monitoring which shall control all Intelligent Addressable Detectors, Manual Call Points and Switching Systems (for disconnecting PAHU and power supply) connected with IP card output for communication with other panel and Main control station.

The Fire alarm control panel shall also give adequate warning signal whenever there is dust accumulation in detectors. It should be possible to change the level of ambient alarm calibration condition by the use of software program.

Short / Open circuit fault shall also be reported at the Fire alarm control panel. In such cases, the system through the use of fault isolators shall be able to isolate that segment. The missing Detectors/Devices shall also be reported at the Fire alarm control panel with identification of the location.

The Fire alarm control panel shall have the facility to set each smoke sensor sensitivity remotely It shall also be possible to set the sensitivity to a high level or low level based on night or day time (time based sensing).

When an alarm condition is sensed at the Fire alarm control panel from a smoke or heat detector, a delay time/alarm verification period shall be started. If the sensor is still in alarm after the delay time expires, an alarm condition is reported. The delay time shall be adjustable from 0 to 990 sec's.

The Fire alarm control panel shall have the facility to perform walk test. In the walk test mode, the performance of each device is checked out by initiating the device. As each device is placed into alarm the Fire alarm control panel shall print the condition and automatically reset the device. Audible devices shall be initiated, if required at a pre-programmed time. If a zone is inadvertently left in walk test mode, it shall automatically reset to normal after the idle time is exceeded. During the walk test the zones other than the programmed zones shall be under continuous supervision (normal mode). In case of any alarm initiated by detector/devices the walk test shall get terminated automatically.

Programming functions shall include alarm/trouble type assignment, point descriptor assignment, alarm message assignment, etc. Programming shall be carried out from the Fire alarm control panel keyboard or utilizing the authorized laptop/desktop computer software.

The Fire alarm control panel shall have a Liquid Crystal Display of Alphanumeric type. The display should have high resolution, backlit 240 character. In case of testing of the system from the Fire alarm control panel the Display shall be able to give readouts of intelligent value of all detectors being tested.

The Fire alarm control panel shall also be able to carry out continuous self monitoring when in normal condition.

The Fire alarm control panel shall also be able to discriminate between false alarms and fire conditions.

The Fire alarm control panel shall carry out priority selection of alarm in case alarm activities in two or more remotely located units simultaneously. In such cases, the Manual call Point shall have the highest priority.

The System shall be fail safe and adequate safe guards should be ensured that in the event of a failure of a part of the System it shall not handicap the complete System.

The agency shall be responsible for preparation and installation of System Software into the Fire Alarm Control Panel. The Software shall be user friendly. The system shall be secured against Software errors.

The system shall have the ability to be upgraded so as to incorporate more features at a later date. The system shall be designed such that it shall be possible to add at least 20% of the Detectors for future expansion without extra cost on the panel.

The Fire alarm control panel shall have its own Battery Backup of a minimum of 48 hours in normal run and then half an hour in alarm condition. The back up time calculation shall be done as per relevant standards and produced for approval. The Battery shall be 2\*12V (24V) DC and of sealed lead acid rechargeable maintenance free type, housed inside the FACP.

The voltage rating shall be from 14V DC to 31V DC, though the voltage may be change.

The Fire alarm control panel shall be totally enclosed dust and vermin proof type made of minimum 13 gauge dust inhibited sheet with even baked finish. The Fire alarm control panel shall be of completely solid state design. The logic circuitry shall be based on high noise immunity solid state hardware employing modular construction. Logic cards shall be of epoxy fiber glass construction.

The Fire alarm control panel shall have UL approval.

The fire alarm panel should be provided with IP integration card.

1.2.2. LOOP - A device loop shall mean a 2-wire circuit connecting minimum 126 addressable detectors/devices per loop. The loop card shall have built-in circuit isolator to accommodate Class 'A' wiring. The loop cards shall be of modular construction for future expansion.

### 1.2.3. ADDRESSABLE DEVICES

*Above term indicates the complete group of addressable devices such as detectors, Manual call points, addressable output/input modules etc.*

### 4.2.4 SMOKE DETECTORS

The Detector shall be intelligent addressable and multi sensing smoke and heat combination. The chamber should be easily removable for the purpose of easy maintenance. The address programming shall be done by a Base/detector or from the Fire alarm control panel. The detectors shall have a common base to allow easy interchange of various types of detectors.

All detectors shall be fitted with plug-in system type, from the maintenance and Compatibility point of views. An alarm condition should not affect a detector's good functioning. After resetting the alarm, the detector shall resume operations without readjustment of any kind. The detector shall have a Multi sensor type integrates photoelectric smoke and fixed temperature heat sensing technology. It shall be possible to use a single detector type for both above and below false ceiling applications. The detector shall be capable of detecting fast flaming fires and slow smouldering fires equally well. The detector shall therefore be a multi technology detector or shall be of unique design whereby a single type/model can be used in applications where either ISD/OSD would be normally used.

The detector shall be able to sense incipient fire by detecting the presence of visible and invisible products of combustion. The detector shall be suitable for low voltage (between 13 to 31V DC) two wire supply. The detector shall be provided with Single/Twin LED indication. The sensitivity of the detector shall not vary with change in ambient temperature, humidity, pressure or voltage variation, air currents and should not trigger the false alarm due to the above condition.

The detector shall be suitably protected against dust accumulation/ingress. The detector shall be free from maintenance and functionally tested at periodic intervals. All detectors shall be identical in construction design and characteristic to facilitate easy replacement and interchangeable by suitable programming.

*The coverage per smoke detector shall strictly follow relevant standards. It shall be possible to connect Smoke Detector with Heat Detector or Manual Push Button in the same circuit.*

The sensitivity of detector shall be set from the Fire alarm control panel to suit the site requirement.

#### 4.2.5 MANUAL CALL POINT

The Manual Call Point shall be addressable type with input modules to define the device/location. The Manual call station shall be breakable type with suitable protection and base box. The device shall be red in colour and suitable for surface or flush mounting. Manual stations shall be interfaced to an addressable input module. The manual station shall have normally open fire alarm and enunciator contacts and these contacts shall close on activation. Contacts shall remain closed until station is manually reset.

The Manual Call Station shall be fully addressable with its own addressable module and operated by digitized signals from the FACP. The voltage range shall be from 13V -31V. It shall have protection as per relevant standard.

#### 4.2.6 OUTPUT MODULE

Output module shall mean addressable points from the Fire alarm control panel with potential free contacts for tripping of AHUs, power supply etc. as required. The system shall also be able to handle separate modules to interface the speakers of the Public Address System.

#### 4.2.7 INPUT MODULE

The input modules shall be of dual/single point type. The dual channel module shall be selectable for Normally Open or closed.

#### 4.2.7 LOOP ISOLATOR

This unit shall be placed on the loop preferably after every 20 devices and shall be able to isolate electrical short circuit in the wiring. All the other detectors shall remain functional because of the Class A wiring of the loop. The isolator shall not utilize an address and shall be built into the detector / base wherever required.

#### 4.2.8 SOUNDERS

The sounders shall be of addressable type/connected by addressable module. The sounders shall derive power from separate cable with voltage adopter. It shall be capable of being directly mounted on the wall/ceiling or along with the detector. The sounder shall have an output of at least 85 db at 1 meter. The sounder shall be programmed to get activated in event of an alarm from a single detector/device or a group of detectors/devices.



#### 4.2.9 HEAT DETECTOR

Heat detector shall go into the alarm mode when the temperature reaches 34 degree Centigrade in normal course. The operator (users) shall have the option of calling up the temperature measured by the specific detector as and when required.

It shall have in-built locking mechanism to check the removal and pilferage of the detector. The quiescent current flow must not exceed 400 micro amps and alarm condition current shall be maximum 40 milli amps.

The heat detector shall be Intelligent Addressable type and be able to send intelligent output to the Fire alarm control panel regarding its condition. It shall be able to communicate with the Fire alarm control panel by the pulses emitted from the Fire alarm control panel. The detector should be addressed through base/detector and address stored in a non-volatile memory within the sensor or by a decade switch.

The base of the Detector shall be electronics free and interchangeable with other smoke or heat detectors. The enclosure shall meet as per the relevant protection grade. The voltage rating shall be between 15V -30V DC though the voltage may be changed depending upon the working voltages of a proprietary FACP.

The Detector shall have UL approval. It shall be possible to test the Detectors working both from the FACP as well as locally. It shall be possible to mount the detectors in Duct Casting Unit for sampling of supplying Air from the AHUs. Secondary response indicators shall be provided for all the Above False Ceiling Detectors.

The detector shall have twin LED's/Single LED for 380/180 degree viewing angle. LED on the detector shall blink each time the sensor is scanned by the Fire alarm control panel. The Fire alarm control panel determines that the sensor is in alarm, the Fire alarm control panel will command the sensor LED to remain on to indicate the same. Each sensor shall be capable of being tested for alarm via command from the Fire alarm control panel each sensor shall respond to Fire alarm control scan with the information about its type for identification.

#### *Strobe*

The strobe light should have lamp supported from fire panel. The lamp shall be fixed with reflector. This should be fixed in ceiling and wall as per the site condition.

### **1.3. BMS Integration**

Fire alarm system shall be integrated with BMS for monitoring. Fire alarm system can be integrated either by

- 1.) Using potential free contacts of Fire Alarm Panels connected to control modules or
- 2.) Using system driver which gives alarm information on individual sensor level to BOS.

In both the cases alarms are relayed to BOS and shown in the integrated graphical user interfaces. Ventilation is shut down in the area concerned.

Fire Alarm system shall integrate to BMS to be able to communicate all Fault and Fire conditions. Fire Alarm system shall be able to communicate to BMS system to turn off PAHU in case of Fire. Fire Alarm system shall be able to communicate to BMS system to release all Fire Doors, Access controlled doors and emergency exits.

## **1.4. Installation**

### 1.4.1. Control Equipment

The equipment should be generally accessible on the ground floor next to the entrance to the building to enable the occupier and the fire brigade to quickly identify the zone in fire.

A plan of the building should be displayed close to the control panel showing entrances, escape routes and zones.

Operating instructions and logbook should be available.

### 1.4.2. Power Supplies

The power supply for the control panel should be exclusive to the fire alarm system. This should be secured from unauthorized use and labelled FIRE ALARM DO NOT SWITCH OFF.

Upon a mains failure the batteries should continue to power the system for a minimum of 24 hours plus 30 minutes alarm duration after that. For an L category system 24 hour battery backup is sufficient, unless otherwise requested. For unoccupied premises the battery backup should be up to 72 hour plus the 30 minute alarm duration. For over 72 hours the system should be monitored by a central station.

### 1.4.3. Cabling & Wiring

All cables for the fire alarm system should be fire proof including the mains supply; these are split in to two categories, standard and enhanced. The standard cable should be a soft skinned type cable and the enhanced should be an FP200 or MICC type cable. Please check with the cable manufacturers for compliance with the British Standards.

## **1.5. Certification**

There are a number of certificates required for the fire alarm installation, these are follows:

- *Design Certificate*
- *Installation Certificate*
- *Commissioning Certificate*
- *Verification Certificate*
- *Acceptance Certificate*
- *Alteration Certificate*
- *Test Certificate*

## **SPECIAL CONDITION FOR SAFETY AT THE WORK SITE**

The contractor will identify one of the supervisors for taking care of implementation of Safety systems.

The Contractor should follow the following General Guidelines governing the safety rules as laid down under:

1. Smoking is strictly prohibited at workplace.
2. Nobody is allowed to work without wearing safety helmet. Chinstrap of safety helmet shall be always on. Drivers, helpers and operators are no exception.
3. No one is allowed to work at or more than three meters height without wearing safety belt and anchoring the lanyard of safety belt to firm support preferably at shoulder level.
4. No one is allowed to work without adequate foot protection.
5. Usage of eye protection equipment shall be ensured when workmen are engaged for grinding, chipping, welding and gas-cutting. For other jobs as and when site safety co-coordinator insists eye protection has to be provided.
6. All safety appliances like Safety shoes, Safety gloves, Safety helmet, Safety belt, Safety goggles etc. shall be arranged before starting the job.
7. All excavated pits shall be barricaded & barricading to be maintained till the backfilling is done. Safe approach to be ensured into every excavation.
8. Adequate illumination at workplace shall be ensured before starting the job at night.
9. All the dangerous moving parts of the portable / fixed machinery being used shall be adequately guarded.
10. Ladders being used at site shall be adequately secured at bottom and top. Ladders shall not be used as work platforms.
11. Material shall not be thrown from the height. If required, the area shall be barricaded and one person shall be posted outside the barricading for preventing the tre-passers from entering the area.
12. Other than electricians no one is allowed to carry out electrical connections, repairs on electrical equipment or other jobs related thereto.
13. All electrical connections shall be made using 3 or 5 core cables, having a earth wire.

14. Inserting of bare wires for tapping the power from electrical sockets is completely prohibited.
15. A tools and tackles inspection register must be maintained and updated regularly.
16. Debris, scrap and other materials to be cleared from time to time from the workplace and at the time of closing of work everyday.
17. All the unsafe conditions, unsafe acts identified by contractors, reported by site supervisors and / or safety personnel to be corrected on priority basis.
18. No children shall be allowed to enter the workplace.
19. All the lifting tools and tackles shall be stored properly when not in use.
20. Clamps shall be used on Return cables to ensure proper earthing for welding works.
21. Return cables shall be used for earthing.
22. All the pressure gauges used in gas cutting apparatus shall be in good working condition.
23. Proper eye washing facilities shall be made in areas where chemicals are handled.
24. Connectors and hose clamps are used for making welding hose connections.
25. All underground cables for supplying construction power shall be routed using conduit pipes.
26. Spill trays shall be used to contain the oil spills while transferring / storing them.
27. Tapping of power by cutting electric cables in between must be avoided. Proper junction boxes must be used.

**(Vinay Kumar Tiwari)**  
Executive Engineer

**LIST OF APPROVED MAKES**

<b>S. No.</b>	<b>Details of Equipment's and materials</b>	<b>Manufacturers Name</b>
1.	Air handling unit/Treated Fresh Air Unit	System Air/Nutech/Flaktwood/ Zeco/Edgetech
a)	Blower	Nicotra/Comferi/ Kruger
b)	Cooling coil	Zeco/Edgetech/ AHRI Certified
c)	Hepa Filter	Thermadyne /Anfilco/ Dyna Air Filtration
2.	Fan Coil Units	Cruise/Zeco/Edgetech/Kubic Midea/Trane
3.	GI Sheets	Bhushan / TATA/ Jindal/SAIL
4.	Duct (factory fabricated)	Rola Star / Techno Fabriduct/Zeco/Ductofab
5.	Pipes (MS & GI)	Tata /Jindal (Hissar)/QST/Jindal(Star)
6.	Gate Valve/ SS Ball Valve	Leader /CIM/ Zoloto / Sant/Honeywell
7.	Butterfly valve	Audco / Advance / Honeywell/Kirlosker
8	Check Valve (Non return valve)	Audco/SKS/Advance/ Zoloto/ Honeywell
9.	Balancing valve	Advance /Audco/ Honeywell/Danfoss
10.	Water strainers (Y-strainer/pot strainer)	Emerald/Sant/D.S. Engineering / Maharaja Casting
11.	Proportional thermostat	Siemens /Honeywell/Johnson
12.	3 Way Motorized/ Mixing / Diverting valves	Siemens /Honeywell/Johnson/Anergy/ Rapid Control/Danfoss
13.	Pressure gauges for water line/Refrigerant	Emerald / Fiebeg/ H. Guru
14.	Thermometers	Emerald/ Japsin
15.	V-Belts	Fenner India/ Dunlop
16.	Fibre glass wool	UP Twiga /Ownes Corning
17.	Nitrile Rubber / closed cells expanded /XLPE	Thermaflex/Armaflex/Eurobatex/Paramount polyethylene foam/Aerolam
18.	Fire retardant flexible duct connection	Air flow / Twiga/ATCO/GP spira/caryaire
19.	Gasket for ducts	Prima Kool / Nuprine
20.	Anchor Fasteners	Hilti / Fischer
21.	Extruded Aluminum grilles & diffusers Fresh air louvers/Dampers	Caryaire/ Ravi Star/ Air Flow/Air master/Titus/System air
22.	Fire damper	Ravi Star/Air Flow/ Mapro/System air/Ruskin Titus/Greenheck
23.	Duct attenuator	AirFlow/Ravi Star/ Continental/Mahajan
24.	Vibration isolators	Resistolex /Gerb / Base/ Dunlop
25.	Motors	Siemens/Crompton/ABB/Bharat Bijlee
26.	Fuse switch unit/switch fuse unit/HRC fuse	Larsen Toubro / Siemens / Schneider (MG)/Havells
27.	Contactors, Timers, O/L relays/Motor	Larsen Toubro/ Siemens / Schneider

	starters	
28.	Control cables	CCI/ Fort Gloster/ Universal/ Incab/ Havells/KEI
29.	Cable glands	Dowells/ Comet/ Peeco
30.	Electrical Panel	Milestone Switchgear Pvt. Ltd/Neptune Systems Pvt. Ltd. / Tricolite Elect. Industries/ESSAAR
31.	Indication lamps and Push Buttons	L&T/ BCH/ Siemens
32.	Ammeters and voltmeters	AEI/L&T/ Rishab / IMP
33.	CTs	AEI/L&T/ Rishab / IMP
34.	MCB	Legrand (MDS)/L & T/ Schnieder
35.	MCCB	L & T/Siemens / Schneider / Legrand (MDS)
36.	XLPE / PVC power cables	CCI/Gloster/Universal/ Havells
37.	Digital LCD energy meter	Enercon / Havells / IMP
38.	Selector Switch	Kaycee/Salzer
39.	Cable Trays	Steel Ways/Slotco
40.	Stick Pins	Primaseal/Airflow
41.	Humidistat	Honeywell/Danfoss/Penn
42.	Condenser/ Chiller	Trane/Carrier/York/Daikin
43.	Polyurethane Foam (PUF)	Malanpur/ Lloyd /Best Opuf
44.	Thermocole	Pioneer/Styrin
45.	Chemical Reagent	Antiscalant/ Descalant / Antifungal Hibird / amacid/ Maic
46.	Centrifugal pump / Monobloc Pump	Grundfoss/Armstrong/Willo/Xylem
47.	Water Softening Plant	Ion Exchange Ltd. / Milton Royal
48.	Pressure switch	Indfoss / Honeywell
49.	Bronze ball valve	Emerald/ Zolto / Leader/ Sant
50.	Bronze ball valve with Y strainer	Emerald / Rapid control/ BAP
51.	VFD with sensors	ABB/DANFOSS/ Siemens
52.	Cooling Tower	Paharpur/Mihir/ Flow air-tech Pvt.Ltd
53.	Cooling Tower PVC Fills	Paharpur/Mihir
54.	Aluminum cable lugs	Alcon (Heavy gauge) / Jainson
55.	Suction guide	Anergy instrument Pvt.Ltd./Johnson
56.	Water cooled screw chilling unit	Trane/Carrier/York/Daikin
57.	Window/Split Air-conditioner/Hi-wall split AC	Voltas/Hitachi / Carrier/Panasonic/Blue star/ Toshiba/Daikin
58.	Dosing pump	M/s Ion Exchange (I) Ltd/ Milton Royal
59.	Chemical reagent	Eco friendly bio clean pond clarifier/ Volga
60.	Sand filter	M/s Ion Exchange (I) Ltd / Pentair.
61.	Compressor	Emerson/Tecumsseh/Bohn/Danfoss
62.	Cold room/Deep freezer	Danfoss/Blue Star/Bohn
63.	Air-cooled ductable split/ceiling mounted Cassette type air-conditioning unit	Voltas/Hitachi / Carrier/Panasonic/Blue star/ Toshiba/Daikin
64.	PVC water tank	Syntex/ Polycon
65.	Water Cooler	Blue Star/Usha/Sidwal/Voltas
66.	Tower AC units	Voltas/Hitachi / Carrier/Panasonic/Blue star/ Toshiba/Daikin
67.	Inverter VRF system	Voltas/Hitachi / Carrier/Panasonic/Blue star/ Toshiba/Daikin/Mitsubishi Electric
68.	Hi wall type chilled water FCU	Cruise/Zeco/Edgetech/Kubic Midea/Trane

69.	Wet scrubber	Zeco/Edgetech/ZAIR
70.	Air washer (Evaporative cooling unit)	Carryaire/Zeco/Zair/Edgetech/Airflow
71.	Pre-Insulated Pipe	Zeco/Permapipe/KC Polymer/AGS Engineering
72.	VAV Boxes	Ruskin Titus/Honeywell/Trox/Trane/Johnson Controls/Tristar
73.	Axial Fans	Krugar/Nicotra/Comefri/Green Deck/Airflow
74.	Spiral Flat Oval Duct (with GSS sheets of approved make)	Dustech/GP spira/Spiral Tubes/Western air ducts/Ductofab /Seven star
75.	Silicone flexible duct connector	Easyflex/Airflow//Resistoflex/Dustech
76.	Motorized butterfly valve/ Modulating Valve/Solenoid valve	Advance/Danfoss/Belimo/Johnson Control/Zoloto/Tyco/Victaulic/Honeywell
77.	Expansion Bellow	Easyflex/Resistoflex/Cori
78.	Fire rated vane Axial/Fire rated tube Axial/Vane Axial/Tube Axial Fan	Nicotra/Comferri/Kruger/Greenheck/Airflow/system air/Zair
79.	Inline Fan	Nicotra/ Kruger/Greenheck/Airflow/system air
80.	Propeller fan	Nicotra/ Kruger/Caryaire/Crompton/GE
81.	Paint/Anti Corrosive coating	Nerolac/Asian/Berger
82.	Self-Cooled PAC sever Rack	Schneider/Emersion/ Flakt
83.	Extruded aluminum powder coated clip-on type covings with Al	Axenic, iclean,GMP ,Fabtech
84.	Light Fixtures	Philips/Havells/Crompton Greaves/Wipro
85.	Cleanroom wall panel	GMP/fabtech/Axenic
<b><i>FIRE ALARM SYSTEM:</i></b>		
1.	Intelligent Addressable Fire Alarm Control panel and Software	Honeywell / Notifier / Johnson Controls/Niagra
2.	Repeater Panel ( At Security Gate)	Honeywell / Notifier / Johnson Controls/Niagra
3.	Intelligent Addressable Multi-sensor detector	Honeywell / Notifier / Johnson Controls/Niagra
4.	Intelligent Addressable Duct sensor detector	Honeywell / Notifier / Johnson Controls/Niagra
5.	Intelligent Addressable Heat type Smoke Detector	Honeywell / Notifier / Johnson Controls/Niagra
6.	Addressable Break Glass type Manual Call Point	Honeywell / Notifier Johnson Controls/Niagra
7.	Response Indicator	Local
8.	Sounder cum Strobe	Honeywell / Safeway / Johnson Controls/Niagra
9.	Control Modules	Honeywell / Notifier / Johnson Controls/Niagra
10.	Control Modules	Honeywell / Notifier /Johnson Controls/Niagra
11.	Fault Isolator Module	Honeywell / Notifier /Johnson Controls/Niagra
12.	Monitor Module	Honeywell / Notifier / Johnson Controls/Niagra
13.	Cables	Neolex/ Varsha/ Teleflex/ Fenolex/Polycab
14.	Fire Extinguishers	Safex /Excellent Fire

Note: The makes of any other item not in the above list shall be got approved by Engineer In Charge before execution of the work.