

GUIDELINES AND PROCEDURES FOR
STRENGTHENING OF BUILDINGS

G H F McKenzie (I)
G R McKay (II)
D L Hutchison (III)
Presenting Author: G H F McKenzie

SUMMARY

General design guidelines developed for the New Zealand Ministry of Works and Development for the seismic strengthening of buildings are presented, together with a discussion of the levels of risk associated with alternative levels of strengthening and the economic comparison of those alternatives.

A variety of approaches to strengthening are described. These cover unreinforced masonry buildings and also buildings of reinforced concrete or with structural steel frames incorporating rivetted beam to column joints. Considerations which govern the design of various details are discussed.

INTRODUCTION

The New Zealand Ministry of Works and Development is responsible for assessing the seismic resistance of more than 5,500 state owned buildings, setting guidelines for strengthening schemes and designing and implementing strengthening measures. Most of these buildings were built to earlier codes, and hence do not comply with earthquake resistance requirements of current codes. The worst risks are presented by the unreinforced masonry structures constructed before 1935. About 1,000 of the buildings are in this category, and priority in replacement or strengthening is being given to these.

DESIGN LEVELS FOR STRENGTHENING

Where a building is to be strengthened and refurbished, as an alternative to demolition and replacement to provide an "unlimited" future life, i.e. a future life of more than 50 years, one principle adopted is that the risk to life in the strengthened building must not be significantly higher than the risk in a new building built to present seismic codes. On the other hand, the acceptable property risk is determined on economic grounds.

-
- (I) Chief Structural Engineer, Ministry of Works and Development, Wellington,
New Zealand
- (II) Senior Design Engineer, Ministry of Works and Development, Wellington,
New Zealand
- (III) Senior Design Engineer, Ministry of Works and Development, Wellington,
New Zealand

New Zealand is divided into 3 seismic zones, denoted A, B and C respectively. Zone A has the highest level of seismicity, and for that zone the national design loading code, NZS4203 (Ref. 1), sets levels of design lateral forces which can cope with the building response to an MM9 earthquake, with maximum ground accelerations up to 0.4g. For coping with the very infrequent earthquakes in Zone A that have intensity greater than MM9 reliance is placed on the existence of a greater ductility capacity than the minimums called for by the provisions of NZS4203.

It is necessary to decide on the minimum permissible seismic strength in Zone A for a building upgraded for unlimited future life. In a number of regions in Zone A the assessed return period for MM9 or greater earthquakes is 220 years and the probability of such an event occurring in a 60 year building life would be approximately 24 percent. For such a high probability of occurrence, a low life risk in an MM9 earthquake is essential. This indicates a minimum strength of $\frac{2}{3}$ of NZS4203 seismic design loads. A building

strengthened to this level is theoretically subjected to a 50% overload in an MM9 earthquake, and withstands it by calling on reserve seismic capacity which includes the ability of shear-wall systems under in-plane loading to deflect a long way beyond the limit of ductile response deformation before collapse. Because of the larger response deformations involved, $\frac{2}{3}$ code level

strengthening will result in greater building damage in strong earthquakes than full code strengthening.

Similar conclusions as to the acceptability of $\frac{2}{3}$ code level strengthening apply in seismic Zones B and C, where NZS4203 sets seismic design loads at 83% and 67% respectively of the Zone A values.

ECONOMIC COMPARISON OF STRENGTHENING OPTIONS

Normal practice of the Ministry is to compare the economics of full code strengthening with $\frac{2}{3}$ code strengthening for each building. Preliminary

designs for the two alternatives are developed far enough to enable rough order of cost estimates to be prepared. The probable average annual seismic damage loss is then calculated by taking for each intensity level on the MM scale the product of the probability of an earthquake of that strength occurring during any 12 month period with the probable damage cost corresponding to such an earthquake, and then summing all such products over the appropriate range of intensities. New Zealand Treasury guidelines require that if \$1,000 of damage are predicted to occur n years after the present date, the present value of that sum must be calculated as \$1,000 divided by 1.1^n . (This rule is based on the premise that any Government capital expenditure project such as a strengthening scheme, should increase in capital value in step with inflation and should also earn an income of at least 10% per year. Hence the present value of an annual seismic damage loss of M summed over a 60 year life of a building would be:-

$$M\left(\frac{1}{1.1} + \frac{1}{1.1^2} + \dots + \frac{1}{1.1^{60}}\right)$$

which is 9.96M.

The sum of the cost of strengthening and refurbishing plus 10M for the full code option is compared with corresponding sum for the $\frac{2}{3}$ code alternative, to obtain the economic comparison. The fact that the level of life risk for the $\frac{2}{3}$ code alternative, although very low, is still greater than that for the full code option is also taken into account.

Strengthening for limited life is also considered as an alternative. A strengthening scheme that will achieve $\frac{1}{2}$ code seismic strength is considered as an acceptable option if the future life of the building is limited to 25 years and if its cost is less than half replacement cost. The smallest return period in any locality in New Zealand for an earthquake strong enough to cause significant risk to life in a building strengthened to that standard is 220 years, and the risk of such an earthquake occurring during a 25 year period is of the order of 10%. Even though this represents an appreciably greater life risk than a replacement building to full code standard, it is considered acceptable because of the finite period of the life risk. Also, on a national scale, being able to strengthen 2 buildings for the cost of replacing one can even result in a risk reduction, because of the amount of money available each year to replace or strengthen hazardous buildings is limited. However usually the economics of $\frac{1}{2}$ code strengthening does not compare favourably with $\frac{2}{3}$ code strengthening, taking into account the significantly higher life risk and the limited future life. It is only when the $\frac{2}{3}$ code standard requires a different form of strengthening scheme that it may become appreciably more expensive than the $\frac{1}{2}$ code alternative.

Strengthening schemes achieving less than $\frac{1}{2}$ code level are usually not considered because the resulting life risk is too high.

UNREINFORCED MASONRY BUILDINGS

Guidelines for Design of Strengthening

The guidelines set for design of strengthening schemes are as follows:-

1. To Strengthen to Current Code Requirements
 - (a) Strength and Ductility

Strengthen the structure of the building, using materials with predictable properties, to resist the earthquake forces specified in NZS 4203, with sufficient ductility to provide the necessary energy absorption. The S-factor chosen for calculation of the Cd coefficient

Tying of Masonry to Concrete Backing

This is achieved by a combination of epoxy grouted metal ties and adhesion of brickwork to concrete backing. Ties at 1.2 metres centres have sufficient anchorage to resist all face load forces, and the adhesion is relied upon to minimise the risk of small portions of brickwork between ties breaking loose. The surface of the brickwork is cleaned to provide optimum adhesion conditions.

Cavity Walls

These present the problem that, if the backing layer is placed against the inner skin and tied to it, the problem of providing support against face loads to the outer skin arises. Continuation of ties across cavity into outer skin involves costs and problems and there is the risk of corrosion of ties in the cavity in the New Zealand climate. If the building is in grounds which can be planted around the outside walls to keep people away from the walls, no additional tying is provided for the outside skin. The most usual measure adopted is to grout the cavity and rely on the adhesion of grout and the existing wire ties across the cavity to hold the outer skin. Although it is not possible to clean the brickwork surfaces in the cavity, cores taken through walls with grouted cavities have indicated good adhesion where an expansive additive has been used.

Timber Backing Walls

These have shown favourable costs in some schemes, and simply consist of providing a timber structural wall either as a replacement for the inner skin of a cavity wall or else placed against the inner face of a solid masonry wall. Ties grouted into the brickwork are connected to the studs of the timber wall, and plywood sheathing is fixed to the studs to resist in-plane loading. This virtually converts the brick walls to timber framed veneers and it is appropriate for single storied construction.

Thin Coatings

Thin coatings of GRC and steel fibre reinforced concrete applied to both wall faces have been tested by our central laboratories and reported elsewhere (Ref. 3).

On one part of the strengthening work for Wairarapa College, coatings of GRC on the inner face of masonry walls have been used for resisting face loads. On another scheme where the outside of the building was plastered and hence exterior GRC coats were acceptable, one option investigated for reduced costs was GRC coatings on both faces of exterior walls, to provide flexural tension membranes.

Floor Diaphragms

Whenever possible existing floors are utilised by tying them into the new backing for the walls. Existing concrete floors usually have sufficient strength and only require a positive connection to the new backing and any new walls. Existing timber floors on the other hand have been found to require strengthening as well as tying in. Structural plywood or particle

Eccentrically braced frames may be designed for a low SM of 0.64 (in terms of NZS4203) because of their good ductility but difficulty has been experienced in providing stiffness compatibility for a stiff building even for response in the elastic range.

Concentrically braced frames provide better stiffness over the elastic response range, but show a sharp stiffness degradation when cycled in-elastically. Use of such elements requires a special study of deflections at various response levels.

CONCLUSION

Space limitations have restricted any considerations of detail, particularly for structural steel and reinforced concrete buildings. The whole field of strengthening of buildings is in a development situation and it will continue to call for much innovation and testing on the part of designers.

References

1. Including amendments Nos. 1 and 2 and draft amendment A3, NZS4203:1976 Code of Practice for General Design Loadings for Buildings. Standards Association of New Zealand.
2. P M F Yong, Cyclic Testing of a Strengthened in-place Brick Masonry Panel. New Zealand Ministry of Works and Development Central Laboratories Report 5-81/7.
3. D L Hutchison et al. Laboratory Testing of a Variety of Strengthening Solutions for Brick Masonry Wall Panels. 8th World Conference on Earthquake Engineering 1983.
4. PW 81/10/1:1968. Code of Practice : Design of Public Buildings. New Zealand Ministry of Works and Development 1968.
5. P J Wood. Cyclic Testing of a Concrete Encased Rivetted Beam Column Joint. New Zealand Ministry of Works and Development Central Laboratories Report 5-82/2.